


2 2 1

8 9 S U

SARVODAYA
RURAL TECHNICAL SERVICES

CORRESPONDENCE COURSE
ON THE
CALCULATION & DESIGN
OF
GRAVITY WATER SUPPLY SCHEMES

221-89su-7216



LANKA JATHIKA SARVODAYA SHRAMADANA SANGAMAYA (Inc.)

(An approved charity)

Sarvodaya Rural Technical Services

SUMMARY OF THE

GRAVITY WATER SUPPLY DESIGN &

HYDRAULIC CORRESPONDENCE COURSE

PREFACE

This summary contains all the theory and exercise lessons with respective solutions to the Gravity Water Supply Design & Hydraulic Correspondence Course implemented in 1989. This edition is intended as a practical reference book for design and calculation of Village Water Supplies in rural areas, and in particular for SRTS technicians, who have followed this course.

Sri Lanka, August 1989

Heini Pfiffner

Technical Advisor SRTS

ISBN 7216
221 8954

TABLE OF CONTENTS

	PAGE:
<u>ABBREVIATION</u>	3
<u>STANDARD FORMS</u>	4
<u>LESSON NO 1</u> : INTAKE OF SPRINGS	13
DIMENSIONING OF SEDIMENTATION CHAMBER	15
<u>LESSON NO 2</u> : DESIGN PERIOD, POPULATION, WATER DEMAND	17
DESIGN FLOW OF MAINLINE	
SILTBOX -- STORAGE TANK	19
<u>LESSON NO 3</u> : CAPACITY DESIGN OF STORAGE TANKS	22
DISTRIBUTION RATIO	24
<u>LESSON NO 4</u> : TOPOGRAPHIC SURVEYING	27
FLOW RATE, PIPELINE DESIGN	28
<u>LESSON NO 5</u> : COMBINATION OF PIPE SIZES	
DIACRAMMATICAL AND ARITHMETICAL METHOD	33
PIPELINE DESIGN, HYDRAULIC PROFILE	35
<u>LESSON NO 6</u> : EXERCISE 14/a, STANDARD FORM	
"TECHNICAL INFORMATION"	39
FLOW RATES	37
EXERCISE 14/b STANDARD FORM	
"TECHNICAL INFORMATION"	43
FLOW RATES	41
<u>FINAL TEST</u>	45

ABBREVIATIONS

HBG = Handbook of Gravity-Flow Water Systems (Thomas D. Jordan Jnr.)
MST = Manual of Standardization VWS (Sarvodaya Rural Technical Services)
WHO = World's Health Organization
HGL = Hydraulic Grade Line

Q = Flow
L = Distance
H = Head, Height
 \emptyset = (Pipe) Diameter
Qmin. = Minimum Flow
Qmax. = Maximum Flow
Qreq. = Required Flow (Design Flow)
l/sec. = Litre per Second
l/min. = Litre per Minute
l/day = Litre per Day
m/sec. = Meter per Second (Velocity)

FORMS:

Form A = Preliminary Survey (Form A - F available in MST)
Form B = Spring Measurements
Form C = Friction Losses in PVC Pipes
Form D = Hydraulic Profile
Form E = Symbols for Situation Plan
Form F = Headloss through Orifice
Form G = Hydraulic Calculation Variants
Form H = Survey (Situation & Hydraulic)
Form I = Technical Information (I/a)
 Technical Information (I/b)

SARVODAYA RURAL TECHNICAL SERVICES

STANDARD PLANS / REVISED 1988

(Type A : Entrance door, steel)

(Type B : Manhole, concrete)

SILTBOX	
Volume 3001- 8001 (Type A)	S - 01
Volume 3001- 8001 (Type B)	S - 02
Volume 10001-20001 (Type A) With valve chamber	S - 03
Volume 10001-20001 (Type B)	S - 04
Volume 3001- 8001 (Type A) With valve chamber	S - 05
CHAMBER	
Valve 60cm x 45cm	C - 01
Valve 60cm x 100cm	C - 02
Pressure Break / Collection	C - 03
Distribution	C - 04
TANK	
Volume 2M2 / 3M2 / 4M2 / 5M2 (Type A)	T - 01
Volume 2M2 / 3M2 / 4M2 / 5M2 (Type B)	T - 02
Volume 6.5M2 / 8M2 / 10M2 / 12M2 (Type A)	T - 03
Volume 6.5M2 / 8M2 / 10M2 / 12M2 (Type B)	T - 04
Volume 2M2 - 15M2 (Ferro-cement) Drawing 1	T - 05
Volume 2M2 - 15M2 (Ferro-cement) Drawing 2	T - 06
VARIOUS	
Attached tap(s)	V - 01
Stand-pipe "86"	V - 02
Stand-pipe "88"	V - 03

Form A:

PRELIMINARY SURVEY FOR VILLAGE WATER SUPPLIES

Name of village:

Divisional Centre responsible:

District/Electorate/Area:

Population:

Infrastructure:

Sarvodaya activities/previous shramadana work:

Present water condition:

Type of sources available:

Altitude source:.....Altitude consumers:

Protection zone for springs:

Yield of springs: S 1 :..... S 2 :.....

S 3 :..... S 4 :.....

Months of dry season:



Name and address of contact person:

Remarks:

Name of Surveyor:..... Date:.....

Overleaf: Handsketch about the project area and the sources

Friction Losses in PVC Pipes




How to Read the Drawing:

Example:

Design Flow = 0.8 l/s
Pipe Length = 120m
Selected Pipe = 40mm (ISO)
Friction Loss = 7

From Drawing:



Result:

Fr. Loss: 2.65m/100m
Total Loss: 120m x 2.65m/100m = 3.17

FORM C

HYDRAULIC CALCULATION
AND PROFILE

VILLAGE:.....

 SURVEYED BY:.....










 DATE:.....
 CHECKED BY:.....

SCALE VERTICAL 1: 00
 SCALE HORIZONT 1: 000

PIPELINE:
 FROM: TO:

POINT No.		
DISTANCE BETWEEN POINTS		
REDUCED LEVEL	m	
STATIC PRESSURE HEAD	m	
DESIGNFLOW	l/sec	
PIPE SIZE (Type I.S.O.1000)		
FRICITION FACTOR	m/100	
FRICITION HEAD	m	
FRICITION CHAINAGE	m	
DYNAMIC HEAD	m	

SYMBOLS FOR DRAWINGS

SYMBOL	USED FOR	SYMBOL	USED FOR
	PIPE LINE (SUPPLY, DISTRIBUTION)		HOUSES
	EXISTING PIPE LINE		IMPORTANT BUILDINGS
	SPRING WITH PROTECTION ZONE		FOOT PATH
	SILT BOX		ROAD
	VALVE CHAMBER		RAILWAY LINE
	WASH OUT WITH PLUG		PADDY FIELD
	PRESSURE BREAK TANK		RIVERS
	WASH PLACE		FOREST
	STAND PIPE		TEMPLE
	STORAGE TANK		CLIFF, STEEP SLOPE
	WELL		BRIDGE, CULVERT
	WELL WITH HAND PUMP		TEA LAND
	BORE HOLE WITH HAND PUMP		
	NON RETURN VALVE		


F ආකෘති පත්‍රය.
Form F

ජල නලයක් තුළ ඇති රන්දුයක් මගින් වන හිසෙහි හානිය.

Headloss through an Orifice in a Pipe

කරාමයක් තුළ අධික ජල හිසක් බල පවත්වන විට රන්දු තහඩුවක් භාවිතයෙන් එනම් කරාමයක ජලය ලබාදෙන නලය තුළට පිත්තල වලින් තැනූ තහඩුවක් ඇතුළු කිරීමෙන් ඉතාමත් පහසුවෙන් ජලය ගලා යාම හසුරාලිය හැක.

A simple way of regulating the flow at tapstands in case of excessive hydraulic head is through the installation of an orifice plate, i.e. a plate made from brass, into the pipe leading to the tap.



- රන්දුයේ විශ්කම්භය
- D_o = ORIFICE DIAMETER
- පි.වි.පි. නලයේ විශ්කම්භය
- ND = NOMINAL DIAMETER OF PVC PIPE
- පි.වි.පි. නලයේ ඇතුළත විශ්කම්භය
- D_i = INTERNAL DIAMETER OF PVC PIPE

රන්දුයක් මගින් වන හිසෙහි හානිය නලයේ විශ්කම්භය රන්දුයේ ප්‍රමාණය සහ නලය තුළ ජලය ගලන වේගය මත රඳා පවතී.

The headloss through an orifice is dependent on the pipe diameter, size of orifice, and the flowrate through the pipe.

මි-මි 20ට සිට මි. මි. 25 දක්වා නාමික විශ්කම්භ ඇති නල සඳහා සහ තත්පරයකට ලීටර් 0.2ක සැලසුම් ගැලීමක් සඳහා (ස.ගැ.කා.සේ. යෝජනා ක්‍රමවල ඇති කරාමයක ප්‍රමිති සැලසුම් ගැලීම) පහත සඳහන් ආසන්න හිසෙහි හානිත් ලබා ගත හැක.

For a design flow of 0.2 l/sec (standard design flow for a tap in SRTS projects), and for nominal pipe diameters of 20 to 25 mm, the following approximate headlosses may be obtained:

රන්දුයේ විශ්කම්භය D_o (මි.මි.) Orifice Diameter D_o (mm)	රන්දු තුළින් හිසෙහි හානිය (මී) Headloss through Orifice (m)
3.5	59
4.0	34
4.5	21
5.0	13.5
5.5	9
6.0	6.5

Name of Project :

District :

Population :

.....:.....

.....:.....

.....:.....

.....:.....

Sources:	Dry Season:	Wet Season:
Spring	1/sec	1/sec
Spring	1/sec	1/sec
Spring	1/sec	1/sec
	1/sec	1/sec
Total Yield:	1/sec	1/sec

WATER DEMAND

..... x 45 l/day/consumer =

..... x 10 l/day/student =

..... =

Total excl. Growthfactor = xGrowthfactor =l/day

WATER BALANCE DRY SEASON

Total yieldl/sec x 60 x 60 x 24 hrs =

Water demand incl. Growthfactor =

Estimated overflow / shortage =l/day

WATER BALANCE WET SEASON

Total yieldl/sec x 60 x 60 x 24 hrs =

Water demand incl. Growthfactor =

Estimated overflow / shortage =l/day

SEDIMENTATION CHAMBER (Siltbox)

Inlet Qmax wet season (1/sec x 60 x 20)

Inlet Qmin dry season (1/sec x 60 x 20)

Outlet Qmax of Designflow (1/sec x 60 x 20)

Volume chosen

Siltbox 1	Siltbox 2
.....l/20min.l/20min.
.....l/20min.l/20min.
.....l/20min.l/20min.
..... L L

DESIGN FLOWS

	(Qreq)	(Qmax)
Mainline Siltbox - St. Tank 1	$= \frac{1/day}{86400 \text{ sec.}} = \dots\dots\dots 1/sec$	$\dots\dots\dots 1/sec$
Mainline Siltbox - St. Tank 2	$= \frac{1/day}{86400 \text{ sec.}} = \dots\dots\dots 1/sec$	$\dots\dots\dots 1/sec$
Mainline Siltbox - Distr. Chamber	$= \frac{1/day}{86400 \text{ sec.}} = \dots\dots\dots 1/sec$	$\dots\dots\dots 1/sec$
.....	$= \frac{1/day}{86400 \text{ sec.}} = \dots\dots\dots 1/sec$	$\dots\dots\dots 1/sec$
.....	$= \frac{1/day}{86400 \text{ sec.}} = \dots\dots\dots 1/sec$	$\dots\dots\dots 1/sec$

DISTRIBUTION SYSTEM

Water Demand l/day (incl.Growthfac.)
 Distribution Ratio (Parts)
 Pipe Ø for Distribution (Chamber)
 Inlet Qmin l/sec (Dry Season)
 Inlet Qmax l/sec (Ref. Designflow)

Tank 1	Tank 2	Tank 3	Tank 4

STORAGE TANK CALCULATION (For additional tanks use backside)

TANK NO: 1	INLETl/sec		DEMAND		DIFFERENCE	WATER LEVEL
PERIOD	hrs:	liters:	%:	liters:	+ / -	liters:
5.30~ 8.30am	3	30
8.30~11.30am	3	10
11.30~ 1.30pm	2	15
1.30~ 4.00pm	2.5	10
4.00~ 7.00pm	3	30
7.00~ 5.30am	10.5	5
Daily yield = = Daily demand		Overflow =		
Storage Capacity (min.).....L =M3 Tank size chosen =....M3						
Tank is filled withinhrs. (must be less than 10 hrs)						

FLOWDIAGRAM (Handsketch)

Prepared by :.....
 Date :.....
 Tech. Advisor:.....
 Signature :.....

TANK NO: 2	INLET....l/sec		DEMAND		DIFFERENCE	WATER LEVEL
PERIOD	hrs:	liters:	%:	liters:	+ / -	liters:
5.30- 8.30am	3	30
8.30-11.30am	3	10
11.30- 1.30pm	2	15
1.30- 4.00pm	2.5	10
4.00- 7.00pm	3	30
7.00- 5.30am	10.5	5
Daily yield = = Daily demand		Overflow -
Storage Capacity (min.).....L =M3 Tank size chosen =....M3						

TANK NO: 3	INLET....l/sec		DEMAND		DIFFERENCE	WATER LEVEL
PERIOD	hrs:	liters:	%:	liters:	+ / -	liters:
5.30- 8.30am	3	30
8.30-11.30am	3	10
11.30- 1.30pm	2	15
1.30- 4.00pm	2.5	10
4.00- 7.00pm	3	30
7.00- 5.30am	10.5	5
Daily yield = = Daily demand		Overflow -
Storage Capacity (min.).....L =M3 Tank size chosen =....M3						

TANK NO: 4	INLET....l/sec		DEMAND		DIFFERENCE	WATER LEVEL
PERIOD	hrs:	liters:	%:	liters:	+ / -	liters:
5.30- 8.30am	3	30
8.30-11.30am	3	10
11.30- 1.30pm	2	15
1.30- 4.00pm	2.5	10
4.00- 7.00pm	3	30
7.00- 5.30am	10.5	5
Daily yield = = Daily demand		Overflow -
Storage Capacity (min.).....L =M3 Tank size chosen =....M3						

Tank 2 is filled within.....hrs (must be less than 10 hrs)

Tank 3 is filled within.....hrs (must be less than 10 hrs)

Tank 4 is filled within.....hrs (must be less than 10 hrs)



LESSON NO 1 : Chapter 1 : Intake of Spring

Chapter 2 : Dimensioning of Sedimentation Chamber

Chapter 1 : Intake of Spring

Refer to: HBC page -99- 11.1. Introduction

11.2. Site Locations

MST page -9- 2.2. Spring Measurements

2.3. Quality Test of Springs

3.2. Spring Catchments

Example 1.1.

$Q_{max} = 1.5$ l/sec (Spring flow during rainy season)

$Q_{min} = 0.85$ l/sec (Spring flow during dry season)

$L = 25$ m (Distance from spring to siltbox)

$H = 0.7$ m (Head; hight between outlet spring and inlet siltbox)

$\phi = 50$ mm (Outlet pipe springcatchment to siltbox)

$Q_{req} = 1.0$ l/sec (Required design flow)

Question:

Is the selected pipe ϕ of 50mm sufficient?

Do we need an overflow pipe at the catchment?

First Reach:

$$\text{Headloss: } \frac{0.7\text{m}}{25\text{m}} \times 100 = \underline{\underline{2.8\text{m}/100\text{m}}} \text{ or } \underline{\underline{2.8\%}}$$

Second Reach:

Refer to table "Friction Losses in PVC Pipes" (Form C)

Accordingly to this table $Q_{max} = 1.55$ l/sec


Conclusion:

The minimum pipe ϕ should never be smaller than 50mm.

Selected pipe ϕ of 50mm is sufficient because $Q_{max} = 1.55$ l/sec compared to $Q_{req} = 1.0$ l/sec.

One overflow pipe of ϕ 50mm is needed.

Situation to Example 1.1. (Handsketch)



Exercise 1

Design the Intake and Overflowpipe according to the following informations:
Spring flow during rainy season = 2 l/sec. Spring flow during dry season = 1 l/sec. Distance spring to siltbox = 20m ; H = 0.4m
Designflow = 1.4 l/sec. (Refer to example 1.1.)

Use this space for calculation etc.

EXERCISE 1 (Solution)

$$\text{Headloss: } \frac{0.4\text{m}}{20\text{m}} \times 100 = \underline{\underline{2\text{m}/100\text{m} \text{ or } 2\%}}$$

$$\begin{aligned} Q_{\text{max}}: \quad \phi 50\text{mm} &= 1.3 \text{ l/sec} < Q_{\text{req}} \\ \phi 63\text{mm} &= 2.3 \text{ l/sec} > Q_{\text{req}} \end{aligned}$$

Conclusion: For Intake 1 x $\phi 63\text{mm}$ or 2 x $\phi 50\text{mm}$
For overflow springcatchment min. 1 x $\phi 50\text{mm}$
or better 1 x $\phi 63\text{mm}$

Chapter 2 : Dimensioning of Sedimentation Chamber (Siltbox)

Refer to : HBG page -102-104- 11.6. Sedimentation

11.7. Service Pipes

-114-115- 12.1. Introduction

12.2. Settling Velocities

12.3. Detention Time

MST page -9-

3.3. Siltbox

Example 2.1.

Spring Flow: (Inlet)

$Q_{max} = 0.45 \text{ l/sec}$ or 27 l/min

$Q_{min} = 0.25 \text{ l/sec}$ or 15 l/min

Design Flow (Outlet)

$Q_{req.} = 0.30 \text{ l/sec}$

Question:

What is the required volume of the siltbox to allow a minimum retention time of 20 minutes? Selected pipe \emptyset for the outlet is $\emptyset 25\text{mm}$ with a maximum possible flow of 0.4 l/sec. (During rainy season only).

First Reach:

Q_{max} from spring during rainy season (Intake)

$= 0.45 \text{ l/sec} \times 60 = 27 \text{ l/min} \times 20 = 540 \text{ l/20minutes}$

Second Reach:

Q_{max} for outlet pipe $\emptyset 25\text{mm}$

$= 0.40 \text{ l/sec} \times 60 = 24 \text{ l/min} \times 20 = 480 \text{ l/20minutes}$

Third Reach:

Overflow at siltbox (during rainy season only)

$= 540 \text{ l} - 480 \text{ l} = 60 \text{ l/20minutes}$ or 3 l/min

Conclusion:

Siltbox with volume of min 480 l is needed.

Take standard plan of Siltbox V = 500 l

Exercise 2

What is the required volume of the Siltbox?

The following informations are given:

Retention time = 20 minutes

Spring flow Q_{max} = 0.21 l/sec

Q_{min} = 0.16 l/sec

Design flow Q_{req} = 0.20 l/sec

Outlet siltbox = PVC \emptyset 25mm; Q_{max} = 0.3 l/sec

Use this space for calculation etc.

EXERCISE 2 (Solution)

Spring flow Q_{max} = 0.21 l/sec x 60 x 20 = 252 l/20minutes

Minimum volume of siltbox = 252 l / take standardplan $V = 300$ L

Exercise 3

What is the required volume of the Siltbox, and what is the expected over-flow during rainy season at the Siltbox ?

The following informations are given:

Retention time = 20 minutes

Spring flow Q_{max} = 1.60 l/sec

Q_{min} = 1.00 l/sec

Design flow Q_{req} = 0.80 l/sec

Q_{max} = 1.00 l/sec

Use this space for calculation etc.


EXERCISE 3 (Solution)

Spring flow (rainy season) Q_{max} = 1.6 l/sec x 60 x 20 = 1920 l/20minutes

Designflow (outletpipe) Q_{max} = 1.0 l/sec x 60 x 20 = 1200 l/20minutes

Overflow at siltbox (during rainy season only) = 720 l/20minutes

Minimum volume of siltbox = 1200 L / ev. better 1500L



LESSON NO 2 : Chapter 3 : Design Period, Population, Water Demand
Chapter 4 : Design Flow of Mainline Siltbox - Storagetank

Chapter 3 : Design Period, Population, Water Demand

- Refer to: HBG page -27-29-
- 4.1. Introduction
 - 4.2. Design Period
 - 4.3. Population Forecast
 - 4.4. Water Demand
- MST page -9-
- 3.1. Water Consumption

Example 3.1.

Calculate the Water Demand for a village with the following information:

- Population = 450 people
- School = 200 day-students
- Daily Consum. = 45 l per person (Possible due to good spring available)
- Spring Flow = 25 l/min during dry season

Note: For the increase of population and consumption which is about 35% increase over a period of 20 years, as well leakage and wastage of water which is about 10%, it is advisable to take a GROWTHFACTOR of 1.1 - 1.5 to consider the future water demand.

First Reach:

Daily Water Demand

$$450 \times 45 \text{ l/day/consumer} \dots \dots \dots = 20250$$

$$200 \times 10 \text{ l/day/student} \dots \dots \dots = \underline{2000}$$

$$\underline{\underline{22250 \text{ l/day}}}$$

Second Reach:

Design of future Water Demand

$$\text{Growthfactor } 1.5 \times 22250 \dots \dots \dots = \underline{\underline{33375 \text{ l/day}}}$$

Third Reach:

Water Balance (during dry season)

$$\text{Spring yield, } 25 \text{ l/min} \dots \dots \dots = 36000 \text{ l/day}$$

$$\text{Estimated consumption incl. future consum.} = \underline{33375 \text{ l/day}}$$

$$\text{Estimated overflow} \dots \dots \dots = \underline{\underline{2625 \text{ l/day}}}$$

Exercise 4

Calculate the Water Demand as well Water Balance during dry and rainy season for a village with the following informations:

- Population = 150 people
Spring Flow = 0.12 l/sec during rainy season
 0.06 l/sec during dry season
Growthfactor = 1.3 (This factor of 1.3 includes in this example the increase of consumption only, assuming there is no increase of population.)

Use this space for calculation etc.

EXERCISE 4 (Solution)

Daily water demand incl. future demand:

$$150 \times 45 \text{ l/day} = 6750 \text{ l/day} \times 1.3 \text{ growthfactor} = \underline{\underline{8775 \text{ l/day}}}$$

Water balance: (rainy season)

$$\text{Spring yield: } 0.12 \text{ l/sec} \times 86400 \text{ sec.} = 10368 \text{ l/day}$$

$$\text{Consumption incl. future demand} = \underline{\underline{8775 \text{ l/day}}}$$

$$\text{Estimated overflow} = \underline{\underline{1593 \text{ l/day}}}$$

Water balance: (dry season)

$$\text{Spring yield: } 0.06 \text{ l/sec} \times 86400 \text{ sec} = 5184 \text{ l/day}$$

$$\text{Consumption incl. future demand} = \underline{\underline{8775 \text{ l/day}}}$$

$$\text{Estimated shortage} = \underline{\underline{-3591 \text{ l/day}}}$$

Conclusion: During rainy season sufficient water available, see overflow.

During dry season in future shortage of 3591 l/day possible.

Therefore: Rainy season 45 l/day/person / dry season about 35 l/day/person or less, if the population increase.

Chapter 4 : Design Flow of Mainline Siltbox - Storagetank

The Design Flow is calculated by dividing the total consumption per day (Water Demand incl. ey. Growthfactor) by 86400 seconds.

$$\text{DESIGN FLOW } Q_{\text{req}} \text{ (1/sec)} = \frac{\text{Water Demand per Day (l)}}{86400 \text{ (seconds)}}$$

Example 4.1.

We want to know the Design Flow based on the informations given in example 3.1. As there is a sufficient spring yield available as well an estimated overflow during dry season, we can take the estimated Future Water Demand incl. Growth-factor for the calculation of the Design Flow.

$$\text{Design Flow } Q_{\text{req}} = \frac{33375 \text{ l}}{86400 \text{ sec}} = \underline{\underline{0.386 \text{ l/sec}}}$$

Question:

What is the required pipe \emptyset for the mainline siltbox to storagetank assuming the following informations are given:

L = 400m (Distance siltbox - storagetank)

H = 40m (Head; hight between siltbox - storagetank)

$Q_{\text{req}} = 0.386 \text{ l/sec}$

First Reach:

$$\text{Headloss: } \frac{40\text{m}}{400\text{m}} \times 100 = \underline{\underline{10\text{m}/100\text{m} \text{ or } 10\%}}$$

Second Reach:

Refer to table "Friction Losses in PVC Pipes" (Form C)

Accordingly to this table:

Headloss (Frictionloss) 10%, PVC \emptyset 20mm $Q_{\text{max}} = 0.29 \text{ l/sec}$ (to small \emptyset)

10%, PVC \emptyset 25mm $Q_{\text{max}} = 0.49 \text{ l/sec}$ (suitable \emptyset)

Conclusion:

To guarantee the required Design Flow of $Q_{\text{req}} = 0.386 \text{ l/sec}$, we have to select PVC pipe \emptyset 25mm with approximately $Q_{\text{max}} = 0.49 \text{ l/sec}$.

Exercise 5

Calculate the Design Flow and required pipe \emptyset for the pipeline siltbox to storagetank. What is the maximum flow (Q_{max}) of the selected pipe?

The following informations are given:

Daily Water Demand = 22000 l/day (incl. future demand)
Siltbox H = 135m
Storagetank H = 100m
Distance Siltb.- Tank = 700m

EXERCISE 5 (Solution)

$$\text{Designflow : } \frac{22000 \text{ l}}{86400 \text{ sec}} = \underline{\underline{0.25 \text{ l/sec}}}$$

$$\text{Headloss: } \frac{35\text{m}}{700\text{m}} \times 100 = \underline{\underline{5\text{m}/100\text{m} \text{ or } 5\%}}$$

Proposed pipe \emptyset : \emptyset 20mm $Q_{max} = 0.19 \text{ l/sec} \rightarrow$ not sufficient.

$$\underline{\underline{\emptyset 25\text{mm} \quad Q_{max} = 0.33 \text{ l/sec} \rightarrow \text{O.K.}}}$$

Exercise 6

The following information is given:

Village population = 300 people
Growthfactor = 1,4
Spring flow = 0.22 l/sec during rainy season
 0.17 l/sec during dry season
Siltbox H = 121m
Storagetank H = 100m
Distance L = 300m (Siltbox to Storagetank)

Calculate: Water Demand, Water Balance dry season and rainy season,
Design Flow (Q_{req}), Pipe \emptyset Siltbox to Storagetank, Design Flow (Q_{max})
and required Volume of Siltbox.

EXERCISE 6 (Solution)

Daily water demand incl. future demand:

$$300 \times 45 \text{ l/day} = 13500 \text{ l/day} \times 1.4 \text{ growthfactor} = \underline{\underline{18900 \text{ l/day}}}$$

Water balance: (rainy season)

$$\text{Spring yield: } 0.22 \text{ l/sec} \times 60 \times 60 \times 24 = 19008 \text{ l/day}$$

$$\text{Water demand incl. future demand} = \underline{\underline{18900 \text{ l/day}}}$$

$$\text{Estimated overflow} = \underline{\underline{108 \text{ l/day}}}$$

Water balance: (dry season)

$$\text{Spring yield: } 0.17 \text{ l/sec} \times 60 \times 60 \times 24 = 14688 \text{ l/day}$$

$$\text{Water demand} = \underline{\underline{18900 \text{ l/day}}}$$

$$\text{Shortage in future (after 20 years)} = \underline{\underline{-4212 \text{ l/day}}}$$

$$\text{Designflow: } \frac{18900 \text{ l}}{86400 \text{ sec}} = \underline{\underline{0.218 \text{ l/sec}}}$$

$$\text{Headloss: } \frac{21\text{m}}{300\text{m}} \times 100 = \underline{\underline{7\text{m}/100\text{m} \text{ or } 7\%}}$$

$$\text{Mainline Siltbox - Tank} = \underline{\underline{\varnothing 20\text{mm} = 0\text{max} = 0.24 \text{ l/sec}}}$$

$$\text{Siltbox: } 0.22 \text{ l/sec} \times 60 \times 20 = 264 \text{ l/20minutes} \quad \text{take Plan V} = \underline{\underline{300 \text{ l}}}$$

GRAVITY WATER SUPPLY DESIGN & HYDRAULIC CORRESPONDENCE COURSE



LESSON NO 3 : Chapter 5 : Capacity Design of Storage Tanks
Chapter 6 : Distribution Ratio

Chapter 5 : Capacity Design of Storage Tanks

Refer to: HBG page -124-126- 14.1. Introduction

14.2. Necessity for a Reservoir

14.3. Capacity

MST page -11-

3.4. Storage Tank

Consumption pattern

The consumption pattern shown in the HBG page -126- are based upon direct observation of typical villages in Nepal. Although no actual field studies have been done in Sri Lanka to determine the pattern of consumption during the day. SRTS for the purpose of design assumes, that the consumption pattern over the day will roughly be like indicated below:

SRTS Consumption pattern

Hours of the day		Percentage of daily consumption
5.30 am - 8.30 am =	3 hrs	30% of total daily water need
8.30 am - 11.30 am =	3 hrs	10% -"- -"
11.30 am - 1.30 pm =	2 hrs	15% -"- -"
1.30 pm - 4.00 pm =	2.5 hrs	10% -"- -"
4.00 pm - 7.00 pm =	3 hrs	30% -"- -"
7.00 pm - 5.30 am =	10.5 hrs	5% -"- -"
	24 hrs	100%

Example 5.1.

The project population of a village is 350 people.

Safe yield of the source is 0.25 l/sec. (during dry season)

The total daily water demand including growth factor is 20000 l/day.

Calculate the required storage capacity, by using the assumed SRTS - consumption pattern.

PERIOD	INLET		DEMAND		DIFFERENCE	WATER LEVEL
	hrs:	liters:	%:	liters:	+ / -	liters:
5.30- 8.30am	3	2700	30	6000	- 3300	- 3300
8.30-11.30am	3	2700	10	2000	+ 700	- 2600
11.30- 1.30pm	2	1800	15	3000	- 1200	- 3800
1.30- 4.00pm	2.5	2250	10	2000	+ 250	- 3550
4.00- 7.00pm	3	2700	30	6000	- 3300	- 6850) ³
7.00- 5.30am	10.5	9450	5	1000	+ 8450	+ 1600) ⁴
Daily spring yield =		21600) ¹		20000) ²	= Daily demand	Overflow -
Storage Capacity (min.)		6850 L	=	6.85 M3	Tank size chosen =	7 M3

)¹ = Daily spring yield (0.25l/sec x 60 x 60 x 24 = 21600 L)

)² = Daily water demand incl. growthfactor (20000 L)

)³ = The maximum shortfall during the day (-6850 L)

)⁴ = Overflow early morning (1600 L)

Conclusion: The required storage capacity is 6850 L. (The maximum shortfall during the day). This volume is rounded off to the next available standard-plan, lets say recommended volume is 7000 L / 7 m3

After calculating the required storage capacity always check whether the recommended tank(s) will be filled up during the night within 8 hours.

Check: Spring yield 0.25 l/sec x 60 x 60 x 8hrs = 7200 L

Recommended volume of tank = 7000 L = O.K.

Exercise 7 (Solution)

Calculate the required storage capacity for the village described in example 3.1. (one tank only)


PERIOD	INLET 25 l/min.		DEMAND		DIFFERENCE	WATER LEVEL
	hrs:	liters:	%:	liters:	+ / -	liters:
5.30- 8.30am	3	4500	30	10012.5	- 5512.5	- 5512.5
8.30-11.30am	3	4500	10	3337.5	+ 1162.5	- 4350
11.30- 1.30pm	2	3000	15	5006.25	- 2006.25	- 6356.25
1.30- 4.00pm	2.5	3750	10	3337.5	+ 412.5	- 5943.75
4.00- 7.00pm	3	4500	30	10012.5	- 5512.5	- 11456.25
7.00- 5.30am	10.5	15750	5	1000	+ 14750	+ 2625
Daily spring yield =		36000			Daily demand	Overflow -
Storage Capacity (min.)		11456 L	=	11.45 M3	Tank size chosen =	12 M3

Check: Spring flow 25 l/min. x 60 x 8 hrs. = 12000 l = Tank size 12000 l = O.K.

Chapter 6 : Distribution Ratio

If a GWS scheme needs more than one storage tank, it is necessary to allocate the accurate number of consumers benefiting of each tank. Thereafter by knowing the daily water demand of beneficiaries for each tank, the Distribution Ratio can be calculated as shown in the following example.

Example 6.1.



Consumer:

150 people = 10125 l/day
300 day-students = 4500 l/day
Total = 14625 l/day*

Consumer:

80 people = 5400 l/day
Total = 5400 l/day*

* = Total Daily Water Demand incl. Growthfactor.

Distribution Ratio:

$$\frac{\text{Tank A} = 14625 \text{ l/day}}{\text{Tank B} = 5400 \text{ l/day}} = \frac{2.7}{1} = \textcircled{\frac{3}{1}}$$


Conclusion:

As there is sufficient water available we can use instead 2.7 : 1 the ratio 3 : 1 which makes it possible to use standardplan C - 04.

Recommended distribution for 3 : 1 according plan C - 04 is:

For: Tank A (Section A) Tank B (Section B)

$\textcircled{3}$ parts \varnothing 63mm : $\textcircled{1}$ part \varnothing 20mm
or: 3 parts \varnothing 75mm : 1 part \varnothing 25mm



Exercise 8

What is the required pipe ϕ ; Q_{req} and Q_{max} for Section A (spring - tank L=375m) and Section B (spring - tank L=180m).

Refer to example 6.1.

EXERCISE 8 (Solution)

Section B : (safe yield) = $\frac{0.35 \text{ l/sec}}{4} = \underline{0.0875 \text{ l/sec}}$ (Designflow = 0.0625 l/sec)

Section A : (safe yield) = $\frac{0.35 \text{ l/sec} \times 3}{4} = \underline{0.2625 \text{ l/sec}}$ (Designflow = 0.1692 l/sec)

Section A : Designflow = $\frac{14625 \text{ l/day}}{86400 \text{ sec}} = \underline{0.1692 \text{ l/sec}}$

Section B : Designflow = $\frac{5400 \text{ l/day}}{86400 \text{ sec}} = \underline{0.0625 \text{ l/sec}}$

Required pipe ϕ for section A:

Headloss: $\frac{55\text{m}}{375\text{m}} \times 100 = \underline{14.66 \text{ m/100m}}$ $\phi \text{ 20mm } Q_{max} = 0.35 \text{ l/sec (Designflow = 0.2625)}$

Required pipe ϕ for section B:


Headloss: $\frac{70\text{m}}{180\text{m}} \times 100 = \underline{38.88 \text{ m/100m}}$ $\phi \text{ 20mm } Q_{max} = 0.58 \text{ l/sec (Designflow = 0.08)}$

Exercise 9

Calculate the Distribution - Ratio as well the required pipe ϕ ; Q_{req} and Q_{max} for each section. (A, B and C).

Spring
h = 250.00m (siltbox)
Safe yield: 0.7 l/sec

SITUATION



) * = Daily Water Demand incl. Growthfactor.

(Use back-side of this page for calculation etc.)

EXERCISE 9 (Solution)

Distribution system:

	TANK 1	TANK 2	TANK 3
Water demand 1/day :	12800 1/day	20000 1/day	27000 1/day
Distribution ratio:	$\frac{12800}{12800} = 1$	$\frac{20000}{12800} = 1.56$	$\frac{27000}{12800} = 2.1$
Pipe ϕ for distribution:	1 Part = ϕ 20mm	1 1/2 Parts = ϕ 32mm	2 Parts = ϕ 40mm
Inlet Q_{min} (1/sec) :	0.1555	0.2333	0.3111

Section A:

Headloss: $\frac{150m}{600m} \times 100 = 25\%$

Selected pipe ϕ : 25mm $Q_{max} = 0.8$ 1/sec $Q_{req} = 0.7$ 1/sec \rightarrow 4.5 Parts

Section B:

Headloss: $\frac{20m}{280m} \times 100 = 7.14\%$

Selected pipe ϕ : 25mm $Q_{max} = 0.4$ 1/sec (not sufficient) $Q_{req} = 0.5444$ 1/sec
(0.3111 + 0.2333)

32mm $Q_{max} = 0.8$ 1/sec O.K.

2 Parts + 1.5 Parts

better combination of pipe sizes:

assumed $Q_{max} = 0.6$ 1/sec

$\frac{100 \times 15 - (4.5\% \times 280m)}{14.5\% - 4.5\%} = 24m$ ϕ 25mm $Q_{max} = 0.6$ 1/sec (Head 5m)
256m ϕ 32mm


Section C:


Headloss: $\frac{35m}{450m} \times 100 = 7.77\%$

Selected pipe ϕ : 25mm $Q_{max} = 0.42$ 1/sec $Q_{req} = 0.3111$ 1/sec \rightarrow 2 Parts

EXERCISE 9 (Ratio for Distribution Chamber)

(Solution) Sketch in addition to solution of exercise 9





LESSON NO 4 : Chapter 7 : Topographic Surveying

Chapter 8 : Flow Rate, Pipeline Design

Chapter 7 : Topographic Surveying


Refer to: HBG page -16-26- 3.1. Introduction

- 3.3. Barometric Altimeter
- 3.4. Abney Level (Clinometer)
- 3.8. Surveying with the Abney (Clinometer)

As it commonly happens within SRTS the topographic survey is divided up in two separate surveys. One for the so called "Situation - Survey" and the other one for the "Hydraulic - Survey". The situation survey indicates all the important marks as roads, rivers, houses etc. The hydraulic survey indicates the alignment of the pipeline from the source to the storage tank and the distribution to the standposts. These two surveys are needed to draw the final situation plan, normally to scale 1:5000. Beside using the standard form H for surveying, it is advisable to maintain at the same time a freehandsketch of the plan, to mark all survey points or other important fix-points.

Example 7.1.

Sketch of Hydraulic Survey (By using a copy of the previous made situation plan, scale 1:5000).



Chapter 8 : Flow Rate & Pipeline Design

Refer to: HBG page -58-73- For introduction and general information.

MST page -11- 3.5. Distribution System

3.6. Piping

Flow Rate


The required flow rate depends on the number of consumer at each tap. The minimum flow rate for one tap is 0.10 l/sec. (0.05 l/sec.). If many consumer are expected at the same tap, the flow rate has to be increased to 0.2 l/sec.

In general use the following recommended flow rates:

1	Tap minimum flow	= 0.10 l/sec	
2	-"-	= 0.20 l/sec	
3	-"-	= 0.30 l/sec	
4	-"-	= 0.35 l/sec	
5	-"-	= 0.40 l/sec	
6	-"-	= 0.45 l/sec	<u>For every extra tap add 0.05 l/sec</u>

Example 8.1.

Sketch of Flow Rate Design (Refer as well to example 7.1.)



Exercise 10


Pipeline Design of Section 3. (Refer also to sketch of example 8.1.)

Distance:

Tank - Pt.5 = 185m

Pt.5 - Tap 1 = 70m

Key Plan of
Section 3



Exercise 11

Pipeline Design of Section 1. (Refer also to sketch of example 8.1.)

Distance:


Tank - Tap 2 = 200m

Tap 2 - Tap 3 = 130m

Tap 3 - Pt. 8 = 70m

Pt. 8 - Tap 4 = 130m

Tap 4 - Tap 5 = 70m



Key Plan of
Section 1

Question to Exercise 10 and 11

Work out the most suitable pipeline design for section 1 and 3. Use enclosed Hydraulic Calculations - Variants Form G.

In addition to Exercise 10 make use of the Formula "Combination Pipe Sizes" as described in the HBC on page -71-72- to guarantee a Residual Head or Dynamic Pressure Head of 5m at Tap 1. ($H = 15.00 - 5.00 = 10.00m$)

We will finalize the Hydraulic Profile for the sections 1-3 during the Intermediate Seminar. Please send your Calculations - Variants in advance.

Point NO	Distance l m	Static head m	Pipe ϕ mm	Tap NO	Flow rate l/s	Friction loss rate	Friction loss m	Friction chainage	Dynamic pressure head	Remarks
Exercise 10 (Section 3) Solution										
Tank/T1	255	15	20	1	0.2	5.25		13.38	1.62	not sufficient
Tank/T1	255	15	(25)	1	0.2	2.05	4.61	4.61	10.39	O.K.
Exercise 11 (Section 1) Solution										
Tank/T2	200	15	(32)	4	0.35	1.75	3.5	3.5	11.5	O.K.
T2/T3	130	25	(25)	3	0.3	4.25	5.52	9.02	15.98	O.K.
T3/T4	200	35	25	2	0.2	2.0	4.00	13.02	21.98	
T4/T5	70	30	20	1	0.1	1.5	1.05	14.07	15.93	
T3/T4	200	35	(20)	2	0.2	5.25	10.50	19.52	15.48	O.K.
T4/T5	70	30	(20)	1	0.1	1.5	1.05	20.57	9.43	O.K.
Tank/T2	200	15	25	4	0.35	5.5	11.00	11.00	4.00	not sufficient

Task in addition to Exercise 10 (Solution)

Used formula "Combination Pipe Sizes" as described in HBG page -71-72-

H = desired headloss, 15m - 5m = 10m

L = total pipelength, 255m

X = small size pipelength, ? (m)

F1 = frictionl. factor large pipe, ϕ 25mm = 2%

Fs = frictionl. factor small pipe, ϕ 20mm = 5.3%

$$X = \frac{100H - (F1 \times L)}{Fs - F1} = \frac{100 \times 10 - (2 \times 255)}{5.3 - 2} = \frac{490}{3.3} = \underline{148m \ \phi \ 20mm}$$

Conclusion:


107m pipe ϕ 25mm

148m pipe ϕ 20mm

HYDRAULIC CORR. COURSE
INTERMEDIATE SEMINAR

HYDRAULIC PROFILE

SCALE VERTICAL: 1/500
SCALE HORIZONTAL: 1/2000




Hydraulic Profile of
Example 8.1. Section 2
on page - 29 -

DATE: 20.04.89 H.A.

Point No	T	Pt.6	T6	Pt.10	T7	
Distance between points	m	100	120	50	80	
Reduced level	m	100.00	85.00	75.00	60.00	80.00
Static pressure head	m	0.00	15.00	25.00	40.00	20.00
Design flow	l/sec.	0.3	0.3	0.2	0.2	
Pipe size (Type ISD 1000)		∅ 25mm	∅ 25mm	∅ 25mm	∅ 25mm	
Friction factor	m/100m	4.25	4.25	2.00	2.00	
Friction head	m	4.25	5.10	1.00	1.60	
Friction charge	m		4.25	9.35	10.35	11.95
Dynamic head	m		10.75	15.65	29.65	8.05

GRAVITY WATER SUPPLY DESIGN & HYDRAULIC CORRESPONDENCE COURSE




LESSON NO 5 : Exercise 12 : Combination of pipe sizes

Diagrammatical and arithmetical method

Exercise 13 : Pipeline Design and Hydraulic Profile

Exercise 12

Calculate the length and diameter of the smaller-sized pipe and larger-sized pipe to guarantee a desired natural maximum flow of 0.8 l/sec.



For diagrammatical method use Vertical Scale 1:1000 / Horizontal Scale 1:5000.
For arithmetical method use Formula HBG page -72- / -203-

Use this space for calculation (arithmetical method)

Exercise 12 (Solution)

1. Reach: Maximum head loss $\frac{200m - 60m}{1200m} \times 100 = \underline{11.66\%}$

2. Reach: Refer to friction loss table.

By frictionloss 11.66% ϕ 25mm = 0.52 l/sec. (Q_{max})

.... ϕ 32mm = 1.00 l/sec. (Q_{max})

3. Reach: Combination of pipe size ϕ 25mm & ϕ 32mm possible.

Refer to formula page - 31 - or HBG page - 72 -

L = 1200m

X = ?

Fs = ϕ 25mm; 24%

F1 = ϕ 32mm; 7.5%

H = 140m

$$X = \frac{100 \times 140 - (7.5 \times 1200)}{24 - 7.5} = \frac{5000}{16.5} = \underline{303m}$$


Conclusion:

303m pipe ϕ 25mm

897m pipe ϕ 32mm

Use this space for diagrammatical method

$h = 140\text{ m}$



Horiz. Scale = 1:5000
Vert. Scale = 1:1000

$\sim 900\text{ m } \phi 32\text{ mm}$


$\sim 300\text{ m } \phi 25\text{ mm}$

HYDRAULIC CALCULATION
AND PROFILE

Exercise 13
HYDRAULIC CORR. COURSE
SURVEYED BY:
DATE:

SCALE VERTICAL 1:500
SCALE HORIZONTAL 1:5000

PIPELINE:
FROM: TO:
Tank - Tap 5



POINT No.		T 1	T 2	T 3	T 4	T 5	
DISTANCE BETWEEN POINTS		200	180	220	150	300	
REDUCED LEVEL	m	100	80	70	50	60	70
STATIC PRESSURE HEAD	m		20	30	50	40	30
DESIGNFLOW	l/sec	0.4	0.35	0.3	0.2	0.1	
PIPE SIZE (Type I.S.O.1000)		∅ 32	∅ 32	∅ 25	∅ 25	∅ 20	
FRICTION FACTOR	m/100	2.2	1.75	4.20	2.0	1.5	
FRICTION HEAD	m	4.4	3.15	9.24	3.0	4.5	
FRICTION CHAINAGE	m	4.40	7.55	16.79	14.79	24.29	
DYNAMIC HEAD	m	15.60	22.45	33.21	20.21	5.71	



GRAVITY WATER SUPPLY DESIGN & HYDRAULIC CORRESPONDENCE COURSE

LESSON NO 6 : Exercise 14 : Technical Information, Standard-form I/a & I/b

Exercise 15 : Flow-rates


Exercise 14 / a

Calculate all technical informations required for the GWS scheme represented with enclosed Situation Plan, by using new introduced Standard-form I/a & I/b. For the flowdiagram use the space provided on form I/b.

Exercise 15 / a


Calculate and indicate in the table provided minimum Flow-rates required for each pipe-section.

Pipeline-section:	Flow-rate:
Tap 1 - Tap 3	0.1
Tap 2 - Tap 3	0.1
Tap 3 - Tap 4	0.3
Tap 4 - Point 2	0.4
Tap 5 - Point 2	0.2
Point 2 - Point 1	0.6
Tap 6 - Point 1	0.1
Point 1 - Tank	0.7
Tap 7 - Tank	0.2
T10 - Pt.4	0.1
T11 - Pt.4	0.2
Pt.4 - Pt.3	0.3
T9 - Pt.3	0.1
Pt.3 - T8	0.4
T8 - Tank	0.5



Situation Plan (not to scale)
to Exercise 14/a

Source:	Dry Season:	Wet Season:
Spring 1	0.1 l/sec.	0.15 l/sec.
Spring 2	0.15 l/sec.	0.25 l/sec.



12.06.89 H. of

TECHNICAL INFORMATION (GWS only)

FORM I /a

Exercise 14 /a

Name of Project :

District :

Population : ... 335

.....

.....

.....

Sources:	Dry Season:	Wet Season:
Spring 1	0.10 l/sec	0.15 l/sec
Spring 2	0.15 l/sec	0.25 l/sec
Spring	1/sec	1/sec
	1/sec	1/sec
Total Yield:	0.25 l/sec	0.40 l/sec

WATER DEMAND

.. 335 .. x 45 l/day/consumer = .. 15075 ..

..... x 10 l/day/student =

Health Clinic = .. 3000 ..

Total excl. Growthfactor = .. 18075 .. x 1.3 Growthfactor = .. 23497.5 l/day

WATER BALANCE DRY SEASON

Total yield 0.25 l/sec x 60 x 60 x 24 hrs = .. 21600 ..

Water demand incl. Growthfactor = .. 23497.5 ..

Estimated ~~overflow~~ / shortage = .. -1897.5 l/day

WATER BALANCE WET SEASON

Total yield 0.40 l/sec x 60 x 60 x 24 hrs = .. 34560 ..

Water demand incl. Growthfactor = .. 23497.5 ..

Estimated overflow / ~~shortage~~ = .. 11062.5 l/day

SEDIMENTATION CHAMBER (Siltbox)

(0.4) Inlet Qmax wet season (1/sec x 60 x 20)

(0.25) Inlet Qmin dry season (1/sec x 60 x 20)

(0.37) Outlet Qmax of Designflow (1/sec x 60 x 20)

Volume chosen

Siltbox 1	Siltbox 2
.. <u>480</u> .. l/20min. l/20min.
.. <u>300</u> .. l/20min. l/20min.
.. <u>444</u> .. l/20min. l/20min.
.. <u>500</u> .. L L

DESIGN FLOWS

	(Qreq)	(Qmax)
Mainline Siltbox - St. Tank 1	= $\frac{1/\text{day}}{86400 \text{ sec.}}$ = .. <u>11.45</u> l/sec l/sec
Mainline Siltbox - St. Tank 2	= $\frac{1/\text{day}}{86400 \text{ sec.}}$ = .. <u>11.45</u> l/sec l/sec
Mainline Siltbox - Distr. Chamber	= $\frac{23500 \text{ l/day}}{86400 \text{ sec}}$ = .. <u>0.271</u> l/sec	<u>0.37</u> l/sec ($\varnothing 20 \text{ mm}$)
Distr. Chamber - Tank I	= $\frac{11700 \text{ l/day}}{86400 \text{ sec}}$ = .. <u>0.135</u> l/sec	~ <u>0.60</u> l/sec ($\varnothing 20 \text{ mm}$)
Distr. Chamber - Tank II	= $\frac{11797 \text{ l/day}}{86400 \text{ sec}}$ = .. <u>0.136</u> l/sec	<u>0.22</u> l/sec ($\varnothing 20 \text{ mm}$)

DISTRIBUTION SYSTEM


Water Demand 1/day (incl.Growthfac.)
 Distribution Ratio (Parts)
 Pipe Ø for Distribution (Chamber)
 Inlet Qmin 1/sec (Dry Season)
 Inlet Qmax 1/sec (Ref. Designflow)

Tank 1	Tank 2	Tank 3	Tank 4
11700	11797.5		
1	1		
25mm	25mm → (after red. to 20mm)		
0.125	0.125		
~0.60	0.22		


STORAGE TANK CALCULATION (For additional tanks use backside)

TANK NO: 1+2	INLET 0.125 l/sec		DEMAND		DIFFERENCE	WATER LEVEL
PERIOD	hrs:	liters:	%:	liters:	+ / -	liters:
5.30- 8.30am	3	1350	30	3510	- 2160	- 2160
8.30-11.30am	3	1350	10	1170	+ 180	- 1980
11.30- 1.30pm	2	900	15	1755	- 855	- 2835
1.30- 4.00pm	2.5	1125	10	1170	- 45	- 2880
4.00- 7.00pm	3	1350	30	3510	- 2160	- 5040
7.00- 5.30am	10.5	4725	5	585	+ 4140	- 900
Daily yield	=	10800		11700 = Daily demand		Overflow
Storage Capacity (min.)	5040 L		= 5.04 M3		Tank size chosen = 5 M3	
Tank is filled within ~ 11 hrs. (must be less than 10 hrs)						

FLOWDIAGRAM (Handsketch)



Prepared by :
 Date :
 Tech. Advisor:.....
 Signature :



GRAVITY WATER SUPPLY DESIGN & HYDRAULIC CORRESPONDENCE COURSE

LESSON NO 6 : Exercise 14 : Technical Information, Standard-form I/a & I/b

Exercise 15 : Flow-rates


Exercise 14 / b

Calculate all technical informations required for the GWS scheme represented with enclosed Situation Plan, by using new introduced Standard-form I/a & I/b. For the flowdiagram use the space provided on form I/b.

Exercise 15 / b


Calculate and indicate in the table provided minimum Flow-rates required for each pipe-section.

Pipeline-section:	Flow-rate:
Tap 1 - Tap 3	0.2
Tap 2 - Tap 3	0.1
Tap 3 - Tap 4	0.4
Tap 4 - Point 2	0.5
Tap 5 - Point 2	0.2
Point 2 - Point 1	0.7
Tap 6 - Point 1	0.1
Point 1 - Tank	0.8
Tap 7 - Tank	0.2
T12 - T11	0.1
T11 - Pt.3	0.2
T10 - Pt.3	0.1
Pt.3 - T9	0.3
T9 - Tank	0.4
T8 - Tank	0.2



Situation Plan (not to scale)
to Exercise 14/b

Source:	Dry Season:	Wet Season:
Spring 1	0.2 l/sec.	0.3 l/sec.
Spring 2	0.1 l/sec.	0.15 l/sec.



Exercise 14 / b

Name of Project :

District :

Population : .. 320 ..

Sources:	Dry Season:	Wet Season:
Spring 1	0.2 l/sec	0.3 l/sec
Spring 2	0.1 l/sec	0.15 l/sec
Spring	1 l/sec	1 l/sec
	1 l/sec	1 l/sec
Total Yield:	0.3 l/sec	0.45 l/sec

WATER DEMAND

.. 320 .. x 45 l/day/consumer = .. 14400 ..

..... x 10 l/day/student =

Health - Clinic = .. 2500 ..

Total excl. Growthfactor = .. 16900 .. x 1.2 Growthfactor = .. 20280 .. l/day

WATER BALANCE DRY SEASON

Total yield .. 0.3 .. l/sec x 60 x 60 x 24 hrs = .. 25920 ..

Water demand incl. Growthfactor = .. 20280 ..

Estimated overflow / shortage = .. 5640 .. l/day

WATER BALANCE WET SEASON

Total yield .. 0.45 .. l/sec x 60 x 60 x 24 hrs = .. 38880 ..

Water demand incl. Growthfactor = .. 20280 ..

Estimated overflow / shortage = .. 18600 .. l/day

SEDIMENTATION CHAMBER (Siltbox)

(0.45) Inlet Q_{max} wet season (1/sec x 60 x 20)

(0.3) Inlet Q_{min} dry season (1/sec x 60 x 20)

Outlet Q_{max} of Designflow (1/sec x 60 x 20)
(0.19 + 0.24)

Volume chosen min.

Siltbox 1	Siltbox 2
.. 540 .. l/20min. l/20min.
.. 360 .. l/20min. l/20min.
.. 516 .. l/20min. l/20min.
.. 500 .. L L

DESIGN FLOWS

Mainline Siltbox - St. Tank 1 = $\frac{8700 \text{ l/day}}{86400 \text{ sec.}}$ = (Q_{req}) 0.09 l/sec

Mainline Siltbox - St. Tank 2 = $\frac{12780 \text{ l/day}}{86400 \text{ sec.}}$ = 0.14 l/sec

Mainline Siltbox - Distr. Chamber = $\frac{1 \text{ l/day}}{86400 \text{ sec}}$ = l/sec

..... = $\frac{1 \text{ l/day}}{86400 \text{ sec}}$ = l/sec

..... = $\frac{1 \text{ l/day}}{86400 \text{ sec}}$ = l/sec

(Q _{max})
0.19 l/sec $0.19 = 0.20$ $0.26 = 0.25$
0.24 l/sec 0.20
..... l/sec
..... l/sec

TECHNICAL INFORMATION (GWS only)

FORM I /b

DISTRIBUTION SYSTEM


Water Demand 1/day (incl. Growthfac.)
 Distribution Ratio (Parts) *(Siltbox)*
 Pipe Ø for Distribution (Chamber)
 Inlet Qmin 1/sec (Dry Season)
 Inlet Qmax 1/sec (Ref. Designflow)

Tank 1	Tank 2	Tank 3	Tank 4
8100	12180		
2	3		
20mm	32mm	→ (after red. acc. th. cl. cal)	
0.12	0.18		
0.19	0.24		

STORAGE TANK CALCULATION (For additional tanks use backside)

TANK NO: 1	INLET 0.12 l/sec		DEMAND		DIFFERENCE	WATER LEVEL
PERIOD	hrs:	liters:	%:	liters:	+ / -	liters:
5.30- 8.30am	3	1296	30	2430	- 1134	- 1134
8.30-11.30am	3	1296	10	810	+ 486	- 648
11.30- 1.30pm	2	864	15	1215	- 351	- 999
1.30- 4.00pm	2.5	1080	10	810	+ 270	- 729
4.00- 7.00pm	3	1296	30	2430	- 1134	- 1863
7.00- 5.30am	10.5	4536	5	405	+ 4131	+ 2268
Daily yield	=	10368		8100	= Daily demand	Overflow
Storage Capacity (min.)	1863 L		=	1.9 M3	Tank size chosen =	2 M3
Tank is filled within	~ 4.5 hrs.		(must be less than 10 hrs)			

FLOWDIAGRAM (Handsketch)



TANK NO: 2	INLET ^{0.18} l/sec		DEMAND		DIFFERENCE	WATER LEVEL
PERIOD	hrs:	liters:	%:	liters:	+ / -	liters:
5.30- 8.30am	3	1944	30	3654	- 1710	- 1710
8.30-11.30am	3	1944	10	1218	+ 726	- 984
11.30- 1.30pm	2	1296	15	1827	- 531	- 1515
1.30- 4.00pm	2.5	1620	10	1218	+ 402	- 1113
4.00- 7.00pm	3	1944	30	3654	- 1710	- 2823
7.00- 5.30am	10.5	6804	5	609	+ 6195	+ 3372
Daily yield =		15552		12180	= Daily demand	
Storage Capacity (min.)		2823	L =	2.8	M3 Tank size chosen = 3 M3	

TANK NO: 3	INLET... l/sec		DEMAND		DIFFERENCE	WATER LEVEL
PERIOD	hrs:	liters:	%:	liters:	+ / -	liters:
5.30- 8.30am	3	30
8.30-11.30am	3	10
11.30- 1.30pm	2	15
1.30- 4.00pm	2.5	10
4.00- 7.00pm	3	30
7.00- 5.30am	10.5	5
Daily yield =		= Daily demand	
Storage Capacity (min.)		L =	M3 Tank size chosen = ... M3	

TANK NO: 4	INLET... l/sec		DEMAND		DIFFERENCE	WATER LEVEL
PERIOD	hrs:	liters:	%:	liters:	+ / -	liters:
5.30- 8.30am	3	30
8.30-11.30am	3	10
11.30- 1.30pm	2	15
1.30- 4.00pm	2.5	10
4.00- 7.00pm	3	30
7.00- 5.30am	10.5	5
Daily yield =		= Daily demand	
Storage Capacity (min.)		L =	M3 Tank size chosen = ... M3	

Tank 2 is filled within..... ^{~ 4.5}hrs (must be less than 10 hrs)
 Tank 3 is filled within.....hrs (must be less than 10 hrs)
 Tank 4 is filled within.....hrs (must be less than 10 hrs)

- 1) The minimum pipe ϕ used for the construction of spring catchments is:
 ϕ 32mm ϕ 40mm ϕ 50mm ϕ 63mm

- 2) The minimum gradient of the pipeline from the spring catchment to the siltbox is:
0.5% 1.0% 1.5% 2% 3% 5%

- 3) The volume of the siltbox should allow a minimum retention time of:
30 minutes 20 minutes 15 minutes

- 4) The permitted maximum static pressure at a tap is:
100m 80m 60m 50m 40m

- 5) The maximum static pressure in PVC pipes (pipelines) should not exceed:
100m 80m 60m 50m 40m

- 6) Taps are distributed in the village, that nobody has to walk more than:
50m 100m 150m 300m

- 7) After calculating the required storage tank capacity we check how many hours during the night are needed to fill the tank. After how many hours should the tank be filled:
6 hours 8 hours -- 10 hours 12 hours

- 8) Calculate design flow, required pipe ϕ for the pipeline siltbox to storagetank. What is the maximum flow (Q_{max}) of the selected pipe ?

Daily water demand = 30240 l/day
Siltbox H = 160m
Tank H = 100m
Distance L = 950m

Use this space for the calculation:

Solution:

Design Flow: $\frac{30240}{86400} = \underline{0.35 \text{ l/sec.}}$

Head Loss: $\frac{60}{950} \times 100 = \underline{6.31\%}$

Proposed pipe ϕ : 25mm ; $Q_{max.} = 0.36 - \underline{0.38 \text{ l/sec.}}$

Combination of pipe sizes:


Siltbox = h 200m
 Tank = h 80m
 L = 1150 m

Desired flow = 0.6 l/sec.

Horizontal Scale: 1:5000
 Vertical Scale: 1:1000

Friction loss fact.
 ↓

∅ 32 mm = $Q_{max.} = 0.96 \text{ l/sec.} \rightarrow 4.6\%$
 ∅ 25 mm = $Q_{max.} = 0.50 \text{ l/sec.} \rightarrow 14.5\%$



V.W.S. of:

Date:

Sheet:

Hydr. Con. Course 89 FINAL TEST

Name:

Point NO	Distance l m	Static head m	Pipe ϕ mm	Tap NO	Flow rate l/s	Friction loss rate	Friction loss m	Friction chainage	Dynamic pressure head	Remarks
Tank/Pt.8	150	35	25	4	0.6	14.5	21.75	21.75	13.25	
Pt.8/T3	90	60	25	3	0.5	10.0	9.00	30.75	29.25	
T3/T2	220	43	25	2	0.4	7.0	15.40	46.15	-3.15	not possible
<u>Second Assumptions:</u>										
Tank/Pt.8	150	35	32	4	0.6	4.5	6.75	6.75	28.25	O.K.
Pt.8/T3	90	60	25	3	0.5	10.0	9.00	15.75	44.25	O.K. (low point)
T3/T2	220	43	25	2	0.4	7.0	15.40	31.15	11.85	O.K. (high point)
T2/T1	150	55	20	1	0.2	5.25	7.87	39.00	16.00	O.K.
Pt.8/T4	80	20	20	1	0.1	1.5	1.20	7.95	12.05	O.K. (high point)

Pipeline section (not to scale)

