


# alternative sanitary waste removal systems for low-income urban areas in developing countries

by  
jens aage hansen & henning therkelsen



309  
7&AL

510

LIBRARY  
International Reference Centre  
for Community Water Supply

**alternative sanitary  
waste removal systems  
for  
low-income urban areas  
in developing countries**

by  
**jens aage hansen & henning therkelsen**

\*Associate professor  
Dep. of Sanitary Engineering,  
Technical University of Denmark,  
DK-2800 Lyngby, DENMARK.

\*\*Research Associate  
Dep. of Civil Engineering,  
University of Washington,  
Seattle, WA 98195, USA.

Trykt 1978 af Polyteknisk Forlag/  
Special-Trykkeriet Viborg a-s

## NOTE

This is a second non-revised printing of the original text published first in March 1977.

A certain updating and definitely an extension of the sanitation concepts and the evaluation methodologies applied have been prepared for the London conference on Engineering, Science and Medicine in the Prevention of Tropical Water Related Disease, arranged by Royal Society of Tropical Medicine and Hygiene, International Association on Water Pollution Research, and Institution of Civil Engineers, 1-7 Great George Street, Westminster, London SW1, UK, 11-14 December, 1978.

Proceedings from this conference will be published by Pergamon Press, and the paper "Appraisal of four alternative excreta removal systems for urban areas in developing countries" by Hansen, Therkelsen and Hansen should be read together with the present book.

## ACKNOWLEDGEMENT

This report was made possible by a research grant from DANIDA, Danish International Development Agency, Copenhagen, Denmark.

Poul Harremoës, Technical University of Denmark strongly advocated that a study on alternative sanitation systems be made. Encouraging - and sometimes discouraging - advice was received from many participants in the WHO/DANIDA training courses on costal pollution control held in Denmark since 1970. Tadayuki Moroshita, Ministry of the Environment, Japan, Oladende O. Oladapo, Lagos State, Nigeria and Kasemsan Suwarnarat, Department of Health, Thailand, all contributed to the work by arranging technical demonstrations on waste and excreta disposal in their respective countries. G. Bactimann, WHO, Geneva, Alexander Velderman, NEDECO-DHV, Holland and John Hebo Nielsen, COWICONSULT, Denmark were kind enough to critically examine the draft report. To all these persons the authors wish to express their sincere appreciation of constructive and most valuable guidance.

Last but not least Lis Asger Hansen organized and typed the inhomogeneous manuscript and Niels Gerhard Nielsen applied his artistic touch to finalize the document. The authors are grateful to these two most amiable and inspiring personalities.

LIBRARY  
International Reference Centre  
for Community Water Supply

# CONTENTS

	Page.
1. SUMMARY, ABSTRACT	1
2. INTRODUCTION, BACKGROUND	5
3. DEVELOPMENT IN SANITATION SYSTEMS	7
3.1 Copenhagen 1765 - 1975	7
3.2 Reversed development	14
4. ALTERNATIVE WASTE DISPOSAL SCHEMES	19
4.1 Systems considered, systems excluded	19
4.2 Complete sanitation schemes	23
5 STUDY AREA SELECTED	25
6. GENERAL EVALUATION CRITERIA & ASSUMPTIONS	29
6.1 Area and housing	29
6.2 Water supply, WS	31
6.3 Waste Water Removal, WWR	33
6.4 Health	33
6.5 Economy	35
6.6 Criteria summarized	40
7. FULL SEWERAGE	41
7.1 Introduction	41
7.2 Plot installations	41
7.3 Sewage collection	41
7.4 Sewage treatment	50
7.5 Base design cost	53
7.6 Cost sensitivity to level of water cons.	55
7.7 Cost sensitivity to slope of sewer lines	58
7.8 Cost sensitivity to slope of land	60
7.9 Cost effect of road pavement	63
7.10 Preliminary FS evaluations	64
8. AQUA PRIVY WITH PIPED LIQUID DISPOSAL	69
8.1 Design considerations	69
8.2 Plot installation, design & cost	69
8.3 Sewage collection	70
8.4 Sewage treatment facilities	73
8.5 Preliminary AP evaluation	73
9. HOUSE VAULT & VACUUM TRUCK	79
9.1 Design & components	79
9.2 Vaults	79
9.3 Vacuum trucks, crews and service areas	79
9.4 Treatment ponds	80
9.5 Preliminary JS & CM evaluations	84

CONTENTS CONT.

	Page.
10. HOUSE BUCKET & ABLUTION BLOCK	91
10.1 Design considerations	91
10.2 Ablution block	91
10.3 Sewage collection system	91
10.4 Sewage treatment system	94
10.5 Preliminary AB evaluation	94
11. MULTRUM	101
11.1 Stage of development	101
11.2 Plot development	102
11.3 Preliminary MR evaluation	104
12. COMPARATIVE EVALUATION	107
12.1 Service levels, WS & WWR	107
12.2 Health	109
12.3 Economy	113
12.4 Employment, supplies & education	121
13. CONCLUSIONS	125
14. REFERENCES	133
15. ABBREVIATIONS	137
16. APPENDICES	139
Appendix I	139
Appendix II	141

## 1. SUMMARY

The main objective for the present report is to investigate alternatives to the traditional Western World sewerage (flush toilet & piped network) for the removal of human wastes from high density, low-cost housing in developing countries.

In order to form a basis for the study it was decided to apply the analysis to a 300 ha area (chapter 5) in the outskirts of Metropolitan Lagos, Nigeria. The geographical conditions include a flat slope of the area and a very high ground water table together with a warm humid climate. However, since such conditions are common in urban areas in developing countries the results herein have a wider applicability. The study discusses 6 alternative technical systems for the removal of sanitary wastewater, and potential combinations of these alternatives were not investigated since detailed contoured maps were not available. The results therefore constitute a comparative evaluation of the different systems for a certain area rather than the "best" overall solution.

The work has been carried out solely on the initiative of the authors, and the proposed systems do not constitute actual design proposals. The choice of study area was made only to achieve a realistic basis for the model calculations.

The following systems have been developed to the extent it was deemed necessary to establish reliable cost estimates:

- o Full (conventional) sewerage
- o Aqua Privy (with piped disposal of the liquid phase)
- o House Vault, Japanese Stool
- o House Vault, Chiang Mai
- o Ablution Block
- o Multrum

The six systems selected for evaluation are based only on existing technology to allow a comparative evaluation in quantitative terms. It must be born in mind, however, that the "Multrum" in the proposed version, cf. chapter 11, has not been proven technically feasible, under the said conditions, and consequently this system does not fully qualify for comparison with the other alternatives.

Cost in monetary terms is an important decision criterion when alternative sanitation systems are considered. The cost sensitivity of each system has been evaluated with respect to:

- o Population density: 125-200-400 p/hectar
- o Interest rate : 0 - 5 - 15%/year

In the case of the conventional sewerage alternative the influence on the total cost of some main parameters have been identified and discussed separately:

- o Water consumption (400, 250 and 125 l/p,d)
- o Slope of main sewers (15, 8, 4 and 2 pm)
- o General slope of area (15 .... 3 pm)
- o Removal & replacement of road pavement


Certain evaluation criteria other than cost, such as local employment and purchase of equipment from foreign countries have also been included in the discussion.

The results indicate that there is no generally applicable optimal solution. Rather the results describe the influence of the project cost as related to basic planning parameters such as population density, service level and available terms for capital loans. On this basis the optimal alternatives for certain conditions are specified.

It is finally concluded that high density urban development favours a piped waste water removal system, though not neces-



sarily of the traditional Western type. The aqua privy and the ablution block seem promising alternatives, particularly where staged development is necessary, e.g. due to scarcity of water supply or capital or both.



## 2. INTRODUCTION, BACKGROUND

Since 1970 the World Health Organization, WHO, has arranged annual training courses on coastal pollution control. The courses are sponsored by the Danish International Development Agency and take place in Denmark with participants from many countries, particularly from the developing areas of Africa, South America, and South East Asia. Repeatedly the participants in their factual statements have described cases with unsatisfactory waste removal conditions that are related to high density "shanty" town settlement - located adjacent to or within capitals or major coastal cities in their home countries.

In such shanty towns people live under extremely primitive conditions, where high population density, poor sanitation, and a warm humid climate form ideal conditions for outbreak of epidemics. For parasitic diseases an endemic situation does often exist.

The solutions proposed to alleviate this problem typically include the conventional sewerage, for example the western type flush toilet with a subterranean piped collection network. This system unfortunately has two prerequisites:

- 1) Water. Self cleaning of the pipes necessitates a high water consumption (app. 50 l/p,d)
- 2) Money. Substantial investments are necessary to introduce sewerage, particularly in already inhabited areas.

Often neither one of these resources is in plentiful supply in developing countries, and there are several examples of extensive planning of water supply and sewerage programmes that have never been implemented, because of such lack of money and adequate water supply cf. the case of Lagos, GILBERT /1/.

Based on these considerations the present report will evaluate and compare technical alternatives for waste water removal from human dwellings in urban areas. With special regard to developing regions low-cost solutions will be emphasized, and high priority will be given to economical evaluations and cost sensitivities to technical modifications.

It could be added that the report is not inventive as to new technology for water supply and waste water removal. Rather an attempt is made to evaluate existing technology and examine if the planners have any significantly different alternatives to choose among.

### 3. URBAN DEVELOPMENT IN SANITATION SYSTEMS

History in itself is fascinating but additionally it may give perspective to new proposals; and often experience of the past is most useful when planning ahead.

Along this line the authors found it interesting to study the development from pit latrines to full sewerage in the city of Copenhagen, a development that took place over a few hundred years and to a certain degree involved almost any concept for excreta removal that is practised even now-a-days in different parts of the world depending on cultural traditions and stage of development.

The sanitary history of Copenhagen will show a rather accidental development and demonstrate a case where poor management rather than technical failure would cause unsatisfactory sanitary conditions to the citizen.

#### 3.1 Copenhagen 1765 - 1975

The first installation for excreta disposal in Copenhagen was the hole in the ground. Some of the holes were emptied by the "nightman" and his crew upon request from the houseowner. Others were simply covered after being filled up, and a new hole was dug in the ground in the backyard. The type of superstructure, the privy, depended on the wealth of the houseowner and the imagination of the carpenter.

Later it became common to have the privy inside the house, e.g. under the stairway. This convenience of direct privy access had some drawbacks, e.g. risk of odour inside the house depending on storage time and ventilation of the privy. Particular inconvenience was experienced when the nightman emptied the storage tank, cf. figure 3.1.1. Sandwiches, warm beer, and a snaps was offered in order to avoid spilling



Figure 3.1.1

Emptying underground tanks involved potential risks of spillages and a very real risk of odour, particularly if the tank was situated inside the house and under the stairway as shown on the painting from HILDEN /2/

and to obtain a swift operation. The nightman had a well paid but lowly esteemed job.

In 1756 it was decreed in Copenhagen that ground tanks be made with brickwalls, and as of 1795 it was no longer permitted to build the privy and ground tank inside the house. In these years the city experienced a growth of population which the existing system was not built for, cf. figure 3.1.2.

Advanced methods of emptying the ground tank were introduced in Germany already before 1880. Figure 3.1.3 shows one of the early versions of the now-a-days very common vacuum trucks, which offer possibilities for excreta removal without any health hazard or great risk of contamination of




Figure 3.1.2 Sanitary development in Copenhagen, facts & dates




Figure 3.1.3 Vacuum trucks were available before 1880 in Germany, operated either manually or automatically, cf. HEIDEN /3/




Figure 3.1.4

The pail privy was proposed in 1797 by H.C. Sonnin, Copenhagen, as an improvement to the ground tank. In the scale 1 alen = .63 meter

the environment during the operation. It is interesting that this concept of excreta removal is widely practised even in 1975 in Tokyo (more than 50% of the population), whereas it never became a generally applied method of excreta removal in cities in Northern Europe. Actually, in Copenhagen the ground tank was practically outruled before the vacuum truck was technically available, cf. figure 3.1.2.

In 1797 SONNIN /4/ proposed a pail latrine, where storage of faeces would be in a portable pail instead of a permanent ground tank. Cf. figure 3.1.4. A refinement of the pail



Marinos Klosetter.




Figure 3.1.5

The Marino toilet was shown at the Health Conference 1858 in Copenhagen, HILDEN /3/

system as apposed to the ground tank was the separation of urine and faeces. The urine is proposed to be led to the yard. The pail would be emptied upon request from the house-owner.

Figure 3.1.5 shows the "Marino" toilet which was discussed at an international health conference in Copenhagen 1858. The "Marino" toilet was also available in an individual chamber version, cf. figure 3.1.6. Compared to Sonnin's proposal of 1797 the principal changes are very modest. The idea of separating urine and faeces was maintained, and it was proposed that this separation lengthens the intervals




Figure 3.1.6 Chamber pot version of Marino's toilet, cf. figure 3.1.5

between emptying the pail. Further the decomposition of faeces would be slowed down and the odour problem diminished in the absence of urine in the pail. Danish experiments in 1850 showed that with separation of urine the fermentation of faeces is insignificant for several weeks, while fermentation is active already 12-18 hours after excretion, if urine be included, HYG.MED. /4/. A resolution from the above mentioned conference recommends that "excreta already separated by nature should be kept separate".

The proposed pail latrine was not readily introduced in practice, neither was the ground tank easily ruled out. In 1865 a survey showed 3050 pail latrines and 510 ground tanks, cf. figure 3.1.2. From the same time another record shows - on the average - one stool per 40-60 persons above age 10 years, HILDEN /2/. The last ground tank disappeared in 1885.

In the 1880's a new variation of the pail system emerged, a pot to pail procedure where the chamber pot was emptied daily into a storage pail, which would then be removed when filled. The advantage was the improved privacy and convenience of having the privy inside the dwelling without long storage. The disadvantage was that some pail privies now were emptied only rarely, and that some storage pails were overflowing due to the popularity of the chamber pot system, HILDEN /2/.

A sewerage system was first proposed in 1853 as a result of 6 years preparation. The proposal was rather revolutionary, consisting of two sewer lines, one for household waste water (grey waste) and storm water, and one for flush toilet sewage (black waste). Ultimately the black waste would be pumped into the deep waters of The Sound (between Sweden and Denmark), the storm water and the grey waste would be discharged into the harbour and the canals of Copenhagen.

1853 also became the year of the first cholera outbreak in Copenhagen, where 5000 people died in three months. And in 1853 the proposal was turned down definitively! Sometimes development requires more than one disaster.

The pail system continued to be in use, cf. figure 3.1.2, and not until the turn of the century should the flush toilet and the combined sewerage become the dominating system for disposal of storm water, grey waste, and black waste. The change occurred during the 1890's, because the pail system failed in four respects, HILDEN /2/:

1. Insufficient cleaning of pails, so that risks of communicable diseases were enhanced, in particular because the empty pail would normally not be returned to the previous user.
2. Insufficient pail capacity with the result that chamber pot emptying caused overflow of the storage pail.
3. Improper decanting of storage pails within the city boundaries.
4. Ineffective ultimate disposal system. The pails were taken to depots within the city boundaries. Often the "depot" was simply the ground surface, where the night soil would accumulate until it was collected by farmers. The system remained poorly managed and the result was obnoxious accumulation of night soil within the city boundary.

The ultimate night soil disposal dilemma called for new solutions. In the 1890's the thinking centered around composting. But, since combined sewerage and flush toilets were now being introduced, the economic background for the composting system disappeared. Also, the slogan "tout a l'égout" was launched in the early 1890's and used by engineers as well as medical people. The number of pails peaked in the beginning of 1900 and then declined to 4600 prior to the Second World War.

### 3.2 Reversed Development

In Copenhagen the flush toilet was introduced only to become all-dominating in relatively short time. Possibly this is a fairly typical solution, at least for a majority of European and American cities. And quite obviously the flush toilet/sewage system has contributed significantly to the well-being of man in many urban communities, particularly in terms of:

- a) less risk of transfer of pathogens when using the toilet.

- b) less direct nuisance (odeur, sight) for the user of the toilet, for the person who handles the waste, and for other persons because the waste is piped underground out of the community instead of being transported above the surface within the city area.


Some problems, though, are linked to the flush toilet/ sewage system. The water consumption is considerable and high quality drinking water is used only to convey faeces from the house to the treatment plant. Costs may be considered high, but in this respect the evaluation is very relative, in the industrialized and developed country the cost is relatively low; in the developing country the cost may be relatively high. The question of costs is dealt with in details in later chapters of this report.

Though very dominating the flush toilet is not all-exclusive in developed countries, for example the pail latrine is still in use in Copenhagen, cf. figure 3.1.2. Furthermore the number of pails is increasing, at least in Scandinavia, cf. figure 3.2.1; for a comprehensive list of alternatives see ORTEGA et al /5/. There seems to be a few typical reasons for seeking alternatives to the traditional flush toilet system even in highly industrialized countries:


1. An attempt to minimize water consumption, which may be in limited supply.
2. A considerable distance to an existing sewerage system, often the case for recreation houses in remote areas.
3. A need for provisional sanitation systems, e.g. in construction areas.

Items 1 and 2 have a certain bearing on conditions in developing countries. Firstly, the limited water supply may be very typical. Secondly, those who install an alternative system, e.g. in a recreation house in a remote area, are often people in a higher income class. This indicates very clearly that an alternative to the flush toilet system should not automatically be judged a "secondary solution".


## PACTO



a)  
INSTALLATION AS A COMPLETE  
UNIT ON TOP OF THE FLOOR



b)  
INSTALLATION PARTLY UNDER  
THE FLOOR WITH ACCESS FROM  
OUTSIDE TO THE COLLECTION  
BAG



c)  
INSTALLATION IN HOUSE WITH  
A BASEMENT

Figure 3.2.1

PACTO toilet (Sweden 1976), commercially available at 600 \$ as a complete "do it yourself" assembly kit. When comparing to figures 3.1.4 - 6 the question arises which one is more developed?

Such attitude has often been expressed in the context that already developed countries "should not export their secondary solutions to developing countries".

These considerations may justify a more careful examination of alternatives to the flush toilet system. They do not necessarily indicate that alternatives are preferable or feasible. It is the intention of this report to evaluate the feasibility of a few alternative sanitation systems for urban settlements in developing countries. And hopefully the findings will constitute factual information to those responsible for new proposals and decisions.





## 4. ALTERNATIVE WASTE DISPOSAL SCHEMES

### 4.1 Systems considered, systems excluded

Five different systems of excreta removal from human dwellings have been adopted for evaluation. Some of these systems are already widely used, e.g. the full sewerage and the house vault system; others have been proposed before but are only little used, e.g. the aqua privy system; and one system, the house bucket/ablution block system which is proposed in the present report, is a hybrid of different systems that are in use, but are not individually satisfactory solutions to urban development projects. The five systems involve 6 different technical approaches, which are briefly introduced below.

#### <sup>10</sup> Full sewerage, FS

The full sewerage is identical to the waste water disposal system that is used conventionally at least in Europe and The United States. The system is included here because it is often referred to as the "only satisfactory long range solution", OLADAPO /6/. Further, the full sewerage will serve as a relevant reference when evaluating other schemes because of its wide application and generally high standard in terms of protection of human health.

Generally FS carries all liquid wastes including suspended and settleable solids. Consequently a relatively high flow is required to keep the system in operation without too frequent cloggings of sewers. A water consumption of app. 50 l/p,d has been proposed, NEDECO /7/.

Details are found in chapter 7

2° Aqua privy, AP

The aqua privy system with piped liquid waste disposal has been proposed by VINCENT et al /8/ for low cost high density housing. Information on the system operation may be found in the same article, but generally the system does not have a widespread use and the information on experience is scarce.

AP will carry all liquid wastes, but settleable solids are precipitated in a subsurface holding tank on the plot before entering a pipe network that conveys the settled sewage to a treatment plant. Because of the tank settling pipes can be laid with very modest slopes without causing clogging problems. Furthermore the minimum required pipediameter is smaller and there is no lower flow limit.

House vault and tanker truck

The house vault is widely used in Japan, e.g. more than 50% of the Tokyo population was served by this system in the early 70'ies, /9/. Even though the system is now systematically being replaced by the FS, the house vault will continue to be used for many years in Tokyo suburbs and other Japanese cities.

The subterranean house vault receives human excreta (faeces & urine) from a vertical duct coming from the stool in the in-house privy. No other wastes are introduced. The vault is emptied regularly (every 2 weeks) by a vacuum truck which transports the night soil to a treatment plant. Two versions of the house vault system will be considered here:

3° Japanese stool, JS.

The system is briefly described above, and further details are given in chapter 9.

4° Chiang Mai Squatting Plate, CM

The CM system differs from the JS by a water seal between the privy and the vault to prevent possible odour nuisance in the privy (a mini siphon is built into the concrete squatting slab). A small amount of water (.8 l) is applied after each use of the privy. Therefore the vault volume for the CM system must be increased compared to the JS system. Further details are given in chapter 9.

5° House bucket and ablution block, AB

The house bucket system is still widely used, e.g. in Lagos/Nigeria, Accra/Ghana, Hong Kong and other places. Emptying necessitates public collection of nightsoil, e.g. every second day, but difficulties are numerous in the operation of this system, partly because it is considered low-status work to collect other people's latrine. Added to this social factor may be a religious consideration that one person ought not handle another persons excreta, ETHIOPIA /lo/. Dissatisfaction with the bucket/night-soil collection is reported e.g. in LAGOS /ll/; but often the lack of satisfaction is also a reason for not reporting, and facts seem to be difficult to obtain on operation of the night soil system.

Public toilet blocks have been installed in several communities in Africa, e.g. in suburban areas of major cities like Tema in Ghana. The operation is often very dissatisfactory because the blocks are not sufficiently attended and users may by negligence or on purpose leave the block unattractive to subsequent users. Lack of use seems to be the rule rather than the exception with public toilet blocks built for community service in many African areas.

Based on such experiences it may seem optimistic to propose a system that combines the house bucket and the public toilet facility. Nevertheless, it is done on the premises that handling of the bucket be a business of the family and that the ablution block be sufficiently attended by public employees to maintain a satisfactory hygienic and aesthetical standard. The evaluation, chapters 10 & 12, in terms of health, economy etc. will indicate whether this concept of waste disposal is promising compared to other alternatives.

6° Multrum, MR

The multrum is basically a compost tank where human excreta and possibly organic kitchen waste will decompose aerobically and provide a compost that could be disposed of on the plot. In this respect the multrum differs from all the other systems, where an off-the-plot disposal is assumed.

Each plot has one privy placed on top of the compost container that is emptied from outside a few times a year. Further details are found in chapter 11.

Only the above six proposed schemes will be considered in the following. There may be other alternatives or variations that would qualify for further consideration, but the authors trust that six systems chosen provide a fair cross section of alternatives that are already wholly or partly in use, and which are often referred to in discussions on alternative sanitation systems in developing areas. The present report aims at providing further quantification and qualification of this discussion.

Many other systems are not included in the present evaluation, because they are deemed less acceptable in an urban high density development area with difficult ground conditions; examples are septic tanks and pit latrines. Such in-


stallations would typically need thorough consideration for more rural settlements or in urban areas with permeable soils, cf. the brief discussion in chapter 6 & 12.

#### 4.2 Complete sanitation schemes

The evaluation of a sanitation system requires consideration of several stages of the water route such as:

1. Water withdrawal
2. Water treatment
3. Water supply
4. Water use } { Plot installations
5. Waste water removal
6. Waste water transport/collection
7. Waste water treatment
8. Waste water disposal
9. Sludge disposal

The analysis in chapters 7 through 11 of this report deals mainly with items 5 - 7, and mainly in technical and economical terms. A more complete evaluation is presented in chapter 12, and criteria for this evaluation are outlined in chapter 6.



## 5. STUDY AREA SELECTED

It was stated in chapter 2 that this study will discuss problems of disposal of sanitary waste in high density urban areas with difficult ground conditions. Since the Ebute Metta area in Lagos, the capital of Nigeria, fits this general description it has been selected as study area.

Lagos is a coastal city with extensive human settlements having only poor sanitary facilities. Certainly Lagos include also city areas with satisfactory and modern sanitation, but such facilities are not available to the majority of the population.

It seems typical for large cities in developing countries that these have a number of non-implemented master plans for water supply and sewerage and Lagos is no exception (7 comprehensive proposals in the period 1926 - 1965). Money was available for preparation of plans but little was spent on sanitary improvements!

The most recent master plan is that of GILBERT /1/ from 1966. With this report at hand, and based on personal experience of both authors, the city of Lagos was chosen as a model study area for a comparative evaluation of alternative sanitation system. The district of Ebute Metta within Lagos, cf. figure 5.1 & 5.2, would realistically meet the criteria with respect to climate, drainage, soil permeability, high ground water table etc. cf. subsequent chapter 6. By this choice the piped waste water systems will come out relatively expensive, because shoring of deep trenches will be necessary and construction more expensive. Consequently alternative sanitation systems, if they exist, would come out economically favourable in this particular comparison.




Figure 5.1

Study region chosen: Lagos, Nigeria






Figure 5.2

Area selected for comparative evaluation of systems: Ebute Metta within metropolitan Lagos

Problems with control of communicable diseases are intensified in the warm and humid climate of Lagos; e.g. malaria is a permanent threat in the wet season. This therefore constitutes another reason to use the Ebute Metta as a model study area for alternative sanitation systems. The Ebute Metta area has a size of app. 286 hectars and would offer housing for only a limited number of people; in the present study between 36000 and 114000 depending on the population density, cf. chapter 6.

## 6. GENERAL EVALUATION CRITERIA & ASSUMPTIONS

A comparison of different technical alternatives necessitates a series of general assumptions and criteria. To the extent possible such criteria are presented here. Certain assumptions, though, that are specifically and exclusively used in a certain chapter may be presented only where applied first time. Detailed tables used for engineering design, e.g. regarding sewerage, are presented in the appendices, chapter 16.

### 6.1 Area and housing

Figure 6.1.1 shows the area within Lagos city boundaries which is chosen as a physical framework for evaluation of each technical alternative. The particular choice of this area is the responsibility of the authors; neither the city of Lagos nor any person in Lagos has expressed the wish to have this study carried out. The area was chosen, however, because of the geotechnical and climatical conditions, i.e. a clayish impermeable soil under tropical temperatures, high precipitation rates and high humidity. Further, several areas of Lagos do have a waste water collection system (night soil collection) which is deemed nonsatisfactory, cf. /11/.

Figure 6.1.1 & 6.1.2 proposes the town plan arrangement and the infrastructure within the road network. Also indicated are the three different population densities that will be used for comparative purposes throughout the report. The housing area totals app. 286 ha, cf. figure 6.1.1, and with due consideration to green belts etc the population numbers shown on figure 6.1.2 have been calculated. The principle of "one family per plot" is maintained throughout the report. This implies that one family occupies one plot of 200 m<sup>2</sup>, and there are 40 plots per hectare.




Figure 6.1.1

Lay-out of housing and transportation within the study area, cf. figures 5.1 & 5.2




Figure 6.1.2 Detailed plot lay-out and alternative population densities

Another fundamental criterion is that maintenance of plot facilities be the responsibility of the occupants. This means for example that a house bucket (cf. the chamber pot system, chapter 3,) would be emptied by a family member and not by publicly employed labour. Thus, the night-soil bucket collection system is excluded from evaluation in the present report. Night soil collection systems are frequently operated with little success, e.g. in Lagos, and that there are often strong emotional reactions to the direct handling of the excreta from other households. Reasons for this attitude could be cultural and religious, ETHIOPIA /12/.

## 6.2 Water supply, WS

It is assumed that public water supply be provided, either by public standpipe or by plot connection:

1. Public standpipes spaced conveniently with regard to distance from individual plots, e.g. max. 150 m from any plot. The public standpipe water supply is satisfactory for the systems MR, AB, JS & CM.
2. Plot tap, at least one per plot. This would satisfy water requirements for waste water systems FS and AP. For JS and MR a plot tap should normally be avoided because waste water cannot be removed adequately.

The cost of the water supply is pertinent to the evaluation of the total costs of a sanitation service. Information as to water supply is unfortunately very poor, but some observations have been provided by WHITE et al. /13/ from studies in East Africa. In general piped water is delivered at a lower price per liter than is water otherwise supplied. The range of variation of prices is experienced to be very broad; WHITE et al. /13 p. 100/ find that even average prices vary from 6.5 \$/cap,y (high density) to 12.6 \$/cap,y (low density) for piped water in urban settlements. Though pertinent mostly to East African conditions and based on a limited number of observations, it is here assumed that WHITE's observations are applicable to indicate an order of magnitude for water supply in the present case.

Table 6.2.1 Assumed water consumption & prices

Population cap/ha	1) Plotpipe-supply			2) Standpipe-supply		
	ℓ/p,d	\$/p,y	\$/plot,y	ℓ/p,d	\$/p,y	\$/plot,y
125	220	13	39	14	2.5	8
200	170	8	40	10	1.8	9
400	90	7	70	9	1.6	16

Notes: 1) WHITE /13, table 4.4/  
 2) WHITE /13, table 4.4 and figure 5.3/

### 6.3. Waste water removal, WWR

For the study area, figure 6.1.1, a general North-South slope of 3 pm is assumed so that the ground drains naturally into the lagoon. The ground water level is assumed 0.5-1 meter below soil surface and the soil impermeable (clay). These conditions compare pretty well to actual conditions in the Lagos area, GILBERT/1/, and in many other major urban settlements in developing countries, e.g. Djakarta & Dacca.

Impermeable soil conditions are not favourable to the construction of a piped waste water removal system because of more difficult trenching. Consequently, when comparing different alternatives the price of a piped system is a priori relatively high and maybe too high for similar sewerage projects in areas with more slope, more permeable soil and lower groundwater table.

The structures for the conveyance of storm water are not included in the subsequent calculations. This assumption will not invalidate the comparison of alternative schemes since it applies equally to all proposals. Open or covered ditches could be suitable for the collection of storm water.

It is proposed that the waste water be treated in facultative oxidation ponds (figure 7.4.2). These ponds are conveniently located in the lowlands between the study area and the lagoon, figure 5.2. Details as to pond design and costs will be presented in the following chapters, particularly no. 7.

### 6.4. Health

The state of human health is controlled by a number of interrelated factors, and waste removal is only one of these. Others are climate, water supply, the general availability of medical care, vaccination programmes, vector control programmes, transportation/communication etc. Thus, the

Table 6.4.1 Identification of some disease transmission routes and biological agents involved

TRANSMISSION		EXAMPLES	
Route	Contraction	Bio-agent	Disease
Water	Ingestion	Salmonella	Typhoid
	Skinpenetration	Schistosomas mans., jap., h.	Schistosomiasis
Anus-hand-hand-man	Ingestion	Shigella	Dysentery
Insect-vectors	Breed in water	Anopheline Culex p. fat. Aedes Aegypti	Malaria Filariasis Yellow & Dengue fever
Food contamination	Ingestion	Salmonella Vibrio Entamoebia	Salmonellosis Cholera Amoebiasis
Man-soil-man	Dirt intake & food contamination	Ascaris Trichuris Necator	Round worm Whip worm Hook worm
Air	Eye & Nose	Aesthetical nuisance, e.g. odeur and unsightly conditions	

assessment of the role of improved waste removal may be very difficult.

The subsequent assessment will be based on the assumption that the transmission of certain communicable diseases is identifiable by mode of contraction and/or type of biological agent (e.g. bacteria & viruses). Consequently, an improved health situation is assumed when a proposed waste removal system significantly impedes the use of a transmission route known to be common in the migration of a certain disease or disease vector. Table 6.4.1 shows a number of specific criteria for such evaluation.



The transmission routes and the model agents listed in table 6.4.1 indicate only a limited number of risks of impaired health; but the examples chosen are important per se, and they represent a number of important possibilities of disease contraction. The risk of infection by the water route is only one among many others, and possibly not the most important one in the present context.

It is important when evaluating improved sanitation to distinguish between effects of improved water supply and effects of improved waste water removal. In the subsequent evaluation water supply is assumed to be based on sources that are located outside the urbanized settlement. The question of separate effects of water supply and waste water removal will be dealt with specifically in chapter 12 (comparative evaluation).

## 6.5. Economy

### 6.5.1 Cost components

In order to obtain economically comparable alternatives the evaluation will include the following items:

1. Plot installation. Facilities necessary to secure collection, e.g. sinks, possible tanks for settleables, laterals, and manholes for a piped system or holding tank or bucket for a non-piped system. Maintenance on the plot is the responsibility and expense of the occupants. Superstructures for privies are not included.
2. Collection All public collection is included whether it be piped or hauled by truck. Basically collection comprises transport from plot to treatment plant.
3. Treatment All treatment costs are included. Pumping after treatment and disposal into the lagoon (brackish) is however excluded.

Details relating to prices and costs are given below in chapters 7 - 11, and in the appendices, chapter 16.

### 6.5.2 Labour, wages

Calculations of labour costs will be based on table 6.5.2.1, which is obtained from ALUKO /14/. The order of magnitude of wages compares well to those suggested by WHO /15/.

Table 6.5.2.1 Wages, Nigeria 1974

---

<u>Employee</u>	<u>\$/month</u>	<u>\$/year</u>
Engineer	300	4000
Driver	80	1000
Labourer	50	600

---

### 6.5.3 Trucks & supplies

Prices for trucks for hauling of excreta are indicated in table 6.5.3.1.

Table 6.5.3.1 Vacuum truck purchase costs

---

<u>Tank capacity</u> <u>m<sup>3</sup></u>	<u>Approximate cost</u> <u>1975 \$</u>
2	10000
3	13000
5	18000

---

Note: Prices based on information from TOKYU /16/

---

To ensure uninterrupted collection service cost of spare parts and extra trucks must be included in any purchase to secure safe collection service also when some trucks are out of operation. Such details including repair are encountered for in subsequent chapters 7 - 11.

Operation costs (e.g. gasoline, tires, lubrication etc) have been established on the basis of long term records for vacuum trucks of the city of Copenhagen. Based on these records it is estimated that - excluding labour and repair - the per hour operation cost is 0.7 \$ (app. 4 Danish Kroner/hour in 1975, stops and evacuation operation included).

#### 6.5.4 Civil works

Detailed cost calculation tables are found in chapter 16, appendix 1.

#### 6.5.5 Present value, user charges, and comparison of alternatives.

The economical evaluation of the different technical alternatives will be based partly on a present value, PV, calculation. The principle and applicability of PV is discussed by WILLIAMS & NASSAR /17/, and it involves a calculation of the present value of all future expenditures and revenues according to the following formula:

$$PV = \sum_q (R_q (1+i)^{-n_q} - E_q (1+i)^{-n_q}) \quad (6.1)$$

where  $R_q$  = future revenue

$E_q$  = future expenditure

$n_q$  = number of years (or a different time period) between present time and future  $E_q$  or  $R_q$

$q$  = enumerator, securing that any R and E be included

$i$  = pro anno interest rate. How to choose  $i$  is discussed below in section 6.5.6.

The use of (6.1) implies that an investor would react according to the following fundamental rules, cf. WILLIAMS /17/:

- 1) It is better to receive to-day than to-morrow, and it is better to pay later than soon.
- 2) It is better to pay less and to receive more.

Based on these principles and eq. (6.1) the investor will always choose among several alternatives the one with the greatest PV. If only expenditures are considered and PV comes out negative the best choice will be the alternative with the smallest negative PV. (In subsequent calculations the sign may be omitted if misinterpretations are not likely).

Calculation of PV may give guidance as to economically optimal alternatives. When combined with other decision variables, e.g. health & general service level (convenience), the overall optimum alternative may be chosen.

However, to the plot occupant or the user of a technical system the PV as calculated by the investor may be irrelevant, because there is no direct relation between a calculated PV figure and the occupant's benefit from the system installed. There may - on the other hand - be a close relation between the project PV and the user charges collected. To the plot owner who has to pay as well as to the investor who will want revenues to cover expenditures it may therefore make sense to indicate directly the user charges necessary to operate the system, e.g. in terms of \$/cap,y or \$/plot,y.

In order to reach such annual user charge the PV can be used according to the following equation:

$$A = PV \frac{i}{1 - (1+i)^{-N}}$$

6-2

where A = annual user charge

PV = present value, cf. eq. (6.1) above

i = interest rate (calculatory) on an annual basis,  
cf. 6.5.6 below

N = expected life time of the system.

Equation (6.2) simply requires that there be exact balance between future expenses (investments and O&M as already built into the PV) and revenues (= user charges) collected throughout the project period of N years that applies to both revenues and expenditures. And this requirement then defines the necessary user charge.

The present value, PV, as well as the user charge, A, will be presented below as results of the economical evaluation in chapter 12.

#### 6.5.6 Interest rates

For use in PV-calculations or estimating user fees a monetary interest rate is necessary. There is no simple way of finding a relevant interest rate, which may depend on the money-market situation or on governmental policies or administrative decisions. Also, the question of inflationary prices becomes very important, when considering project periods where the period between initial investment and final back-payment may amount to e.g. 30 years.

In order to allow for flexible interpretation of economical calculations it is therefore decided to use 3 different interest rates 0, 5, and 15%.

An interest rate of 0% indicates the total cash flows throughout the project period, all in prices for a year of reference; 1975 is used where possible in this report. 5% may be a realistic interest rate on the international capital market assuming that inflation does not have to be accounted for in the calculation of PV (real interest).

15% may be an interest rate that include "real" interest and compensation for inflation.

All three interest rates will be used in subsequent graphs and tables of results.

### 6.6 Criteria summarized

Climate	Tropical, humid
Soil	Impermeable, clayish, high groundwater table (less than 1 meter below surface)
Area	Approximately 286 hectar
Slope of area	3 pm average natural slope available (cost sensitivity to other slopes will also be investigated)
Population density	125, 200 or 400 persons/hectar 40 plots per hectar, each plot 200 m <sup>2</sup> 3,5 or 10 persons/family. Each family handles and maintains the plot instal-lations
Water supply	Public standpipes sufficient for MR, AB, JS & CM  Plot tap indispensable for FS and nor-mally required also for AP. For MR, AB, JS (& CM) the plot tap should not be provided
Waste water removal	Piped systems for FS, AP & AB. Non-piped for MR, JS & CM
Waste water treatment	Oxidation ponds and discharge to the nearby lagoon (brackish/saline water)
Economy	Technical alternatives will be based on a present value, PV, calculation assum-ing a project period of 30 years;cf. 6.5.5.  Interest rates of 0, 5 and 15% will be used to demonstrate how capital inten-sive alternatives may differ from labour intensive ditto.  Assumptions as to unit wages and prices are presented in 6.5.2 & 3 and in chapter 16, appendix I.

## 7. FULL SEWERAGE

### 7.1. Introduction

The presumptive layout of the full sewerage scheme (FS) is indicated on figures 7.1.1 and 7.1.2.

In addition to the evaluation criteria that were mentioned in chapter 6 the following factors will be considered in the cost sensitivity analysis (section 7.6. - 7.9.)

- 1° Level of water consumption
- 2° Gradients of drainage pipes
- 3° Slope of drainage area
- 4° Replacement of paving

### 7.2. Plot installations

Only the cost of a flush toilet and a sink drain in each home has been included in the overall cost estimate. The unit costs applied are as follows:

Flush toilet, Eastern type	: \$ 60
Sink	: \$ 20
Installation & internal piping	: \$ 60
External piping 7 m $\phi$ 100 mm, \$ 8.0/m	: <u>\$ 60</u>
Total cost per home	<u>\$ 200</u>

### 7.3. Sewage collection

#### 7.3.1 Slope of area

The location of the main sewerlines are shown on figure 7.1.1. In the absence of a contoured map it has been assumed that there is an average 3 pm slope available for the trunk sewers. The cost implication of this assumption is evaluated below in section 7.8.




Figure 7.1.1

Major trunk sewers, FS system






Figure 7.1.2 Plot drainage, laterals, mains, and trunk sewers, FS system

Table 7.2.1 Total cost of FS plot installations

Density cap/ha	Cap/plot	Cost/cap \$	1) Total area cost, \$ 1000
125	3	65	2300
200	5	50	2300
400	10	20	2300

Note: 1) Based on a total area of approx. 284 ha and an extra expenditure of \$ 30 000 for public toilets. The assumed lifetime for toilet facilities is 30 years. Maintenance is carried out by the home owners and is thus not included.

### 7.3.2 Network

The structure of plot drainage is shown on figure 7.1.2 Lateral lines extending 5 m onto the plots are connected to the main sewer by a 45° bend and a 45° junction piece. A manhole is located in the trunk sewerline at every junction of a mainline and at any change of slope or direction. In addition manholes are located at the top of all main and trunk sewers.

The storm water collection system is proposed to consist of concrete lined road side ditches at a gradient of approximately 2 pm. The design of the storm water system is not included in this study, but it is necessary to ensure that the storm water ditches do not conflict with the sanitary system. In the upper reaches the storm water ditches will be quite shallow and the sanitary sewers are easily located underneath. Since the slope of main sewers in the base design is considerably greater (8 & 15 pm) than the hydraulic gradient for the storm water ditches the sanitary sewers can always be located below the bottom of the storm water ditches also in the lower reaches of the system. In special cases, particularly when a flat slope of the main sewers (2 - 4 pm) is being considered, special designs have to be implemented probably involving wide rectangular channels (covered) or narrow deep channels (covered) in the middle of the road when trunk sewer connections enter from only one side.

### 7.3.3 Cleaning

Modern jet cleaning equipment is proposed for maintenance, therefore merely a flushing shaft is required midway on the main-sewer lines to facilitate cleaning.

#### 7.3.4 Corrosion

Due to the generally high temperatures in the Lagos area and the low sewage flows in the initial development phases concrete pipes are likely to be attacked by Hydrogen Sulphide from the microbial activity in stale sewage, ref. /18/. Since ventilation through the manhole covers is provided, the corrosion hazard is not critical when the network is designed at a steep slope (15 pm). However, when smaller slopes are employed plastic pipes are alternatively proposed. The total price of sewer installation is essentially the same irrespective of whether the pipematerial is concrete or plastic.

#### 7.3.5 Design criteria

Pipes. Sewers for this scheme are circular rubber ring jointed concrete pipes that are or can be produced locally. Where corrosion is deemed to be a problem, plastic pipes are alternatively proposed. Connections should be made by prefabricated 45° junction pieces.

Minimum pipe size is 150 mm in order to avoid blockings. This minimum diameter is rather large, but it has been experienced that objects such as tin cans, rags and vegetable debris (maize cobs) are often found in sewers.

Manholes. Details of manholes are shown in Appendix I. The different types are used as indicated below:

Type I: Shallow manhole  $\phi$  .8 m, used for laterals only. (one per 2 plots)

Type II: Used on mains and trunk sewers,  $\phi$  250 - 600 mm.

Type III: Used for trunk sewers larger than  $\phi$  600 mm.

Shafts. Narrow flushing shaft  $\phi$  300 mm with rounded junction piece to the sewer line. It is used for jet cleaning purposes only

Laterals. Diameter : 150 mm  
Slope : 20 pm  
Min. depth : 0.9 m

Mains. Diameter minimum: 200 mm  
Slope : 15 pm (base design)

Such great slope will provide selfcleaning and keep pipe corrosion at a minimum. Due to proximity of the sources slugs of water will surge through the near part of the main, thus providing additional cleaning. The sensitivity of cost to slope is discussed later in this chapter.

Trunks. Diameter, minimum: 250 mm  
Slope : 3 pm

For upper ends where the flow is low the slope will have to be increased to ensure self-cleaning, but this will appear to be insignificant to the total estimated cost.

Flow. Dry weather flow, DWF = 85% of the water consumption, cf. /33/

Infiltration inflow. I = 30000 US gal./mile, day  
I = 0.3 l/s, ha, cf. /33/.

The infiltration depends essentially on the quality of the pipes and in particular on the craftsmanship during construction, both of which are presently unknown. For rubber ring jointed pipes the above is a conservative estimate.

Capacity. Lateral and main sewers : 5 DWF + I  
Trunk sewers : 4 DWF + I  
Large trunk sewers : (2-4) DWF + I

Hydraulics.

$$\frac{Q}{F} = v = 72 R^{0.625} I^{0.5} \quad \text{cf. /34/}$$

Q = flow, m<sup>3</sup>/s

F = cross sectional area, m<sup>2</sup>

R = hydraulic radius, m

I = slope, m/m

7.3.6 System design

A design based on a water consumption of 400 l/cap,d is initially developed. Lower levels of water consumption (250 and 125 l/cap,d) are thereafter assumed, in order to identify and discuss the design in terms of sensitivity to this parameter.

It appears from the estimates in tables 7.3.6.2 and 7.3.6.3 that the areas where the slope of the trunk sewer will have to be increased to maintain self cleansing are insignificantly small, and this aspect will therefore not change the cost computation.

Table 7.3.6.1 Design of laterals and mains

Density	Laterals ø 150 mm	Mains ø 200 mm	DWF	3) Required mains' capacity	4) Capacity of ø 200 at 15 pm	Mainte- nance
cap/ha	m/ha	m/ha	l/s,ha	l/s	l/s	
125	190	200	0.5	3.5	42	min
200	190	200	0.8	5.4	42	min
400	190	200	1.6	10.4	42	min
pub. space	50	50	2) 3.0	14	42	min

- Notes: 1) 400 x 0.85 = 340 l/cap,d  
 2) 60 l/cap, 8 h  
 3) 5 DWF + I per ha. Mains are max. 250 m so one main drains at most 1.25 ha.  
 4) Cleaning of occasional blockings. The mains are deemed to be self-cleaning with respect to sand.

Table 7.3.6.2 Capacity of trunk sewers

Diameter mm	Capacity at 3 pm slope ℓ/s	Area drainage capacity 1)		
		125 cap/ha ha	200 cap/ha ha	400 cap/ha ha
250	33	14.3	9.4	4.9
300	54	23.5	15.4	8.1
350	81	35.2	23.1	12.1
400	115	50	32.9	17.2
450	155	67.4	44.3	23.1
500	210	91.3	60	31.3
600	330	143.5	94.3	49.3
700	500	217.4	142.9	74.6
800	720	313	205.7	107.5
900	980	426.1	280	146.3
1000	1150	500	328.6	171.6
1100	1650	720	471.4	246.3

Note: 1) 4 DWF + I, DWF = 340 ℓ/cap,d, I = 0.3 ℓ/s, ha

Table 7.3.6.3 Self-cleaning of trunk sewers

Density cap/ha	2 DWF 1) ℓ/s, ha	For self-cleaning $\tau = 0.25 \text{ kg/m}^2$ 2)		For self-cleaning $\tau = 0.15 \text{ kg/m}^2$	
		flow ℓ/s	area ha	flow ℓ/s	area ha
125	1.0	14	14	7	7
200	1.6	14	9	7	4.5
400	3.2	14	3	7	1.5

Notes: 1) Flow deemed available once a day for pipe cleaning.

2) Eroding force  $\tau = \gamma \cdot R \cdot I$  cf/32/,  $\text{kg/m}^2$   
 $\gamma$  = density of water  $\text{kg/m}^3$   
 $R$  = hydraulic radius, m  
 $I$  = slope, m/m

Min.  $\tau$  values of 0.15 - 0.25  $\text{kg/m}^2$  are recommended under various conditions, cf /32/, to maintain self-cleaning with respect to sand.

3) The area downstream of which the trunk sewer is deemed to be self-cleaning at a slope of 3 pm

Table 7.3.6.4: Quantitative summary of sewers.

	Pipe diam. (mm)	Accumulated length, meters		
		125 cap/ha	200 cap/ha	400 cap/ha
Laterals	150	55030	55030	55030
Mains	200	57890	57890	57890
Trunks	250	5710	4190	2710
	300	2140	1890	1340
	350	560	1690	1100
	400	1230	510	1770
	450	1590	1120	910
	500	750	1250	350
	600	250	1400	1470
	700	1115	180	1750
	800	0	1115	830
	900	0	0	0
	1000	0	0	265
	1100	0	0	850
Trunks total		13345	13345	13345

Notes:

Number of manholes

Manhole	Type	I	5503	5503	5503
	Type II		517	512	463
	Type III		13	18	68
	Flushing shaft		250	250	250

Table 7.3.6.5 Cost of Sewage collection System

Pop. density cap/ha	1)	2)	3)	4)	5) Mainten- ance	
	Laterals \$ 1000	Main sewers \$ 1000	Trunk sewers \$ 1000	Manholes \$ 1000		Sewers total \$ 1000
125	1486	2489	1167	1120	6262	3
200	1486	2489	1230	1122	6327	3
400	1486	2489	1416	1134	6525	3

Notes: 1)  $\phi$  150 mm, average depth 2.5 m at \$27/m  
 2)  $\phi$  200 mm, average depth 3.0 m at \$43/m  
 3) Average depth 5.0 m price see appendix I table 1  
 4) Prices from appendix I, table 2  
 5) Occasional cleaning of blockings by a contractor  
 (supplies \$ 1000 + labour \$ 2000/y)

At a slope of 3 pm a substantial flow is necessary to maintain self-cleaning.

The trunk sewer system is designed on basis of table 7.3.6.2 (see appendix II, chapter 16, for the summarized calculations).

The sewerage design results and preliminary cost estimates are summarized in tables 7.3.6.4 and 7.3.6.5.

#### 7.4 Sewage treatment

Sewage treatment is provided by facultative oxidation ponds which are designed according to the South African design procedure /19, 20, 21/, with primary and secondary ponds.

The ponds are proposed to be built in the low-lying area to the South of Ebute Metta as indicated on figure 5.2. The objective of treatment is to reduce the noxious character of the sewage, and an engineering criteria for the effluent quality has been assessed to 20 mg/l BOD<sub>5</sub>.

##### 7.4.1 Design of oxidation ponds

The following assumptions are made in the design of oxidation ponds:

- Organic loading 55 g BOD<sub>5</sub>/cap day /22/.
- Evaporation approximates precipitation.
- Effluent quality better than BOD<sub>5</sub>=20 mg/l
- The effluent is discharged into the brackish Ebute Metta Creek, which again discharges immediately into the Lagos Lagoon and subsequently into the sea.
- Basic equations /20/

$$P = \frac{P_o}{K_T \cdot R + 1}$$



$$K_T = 1.2 \cdot 1.085^{-(35-T)} \quad T \text{ in } ^\circ\text{C}$$

$$P_1 = \frac{750}{2 \cdot \text{depth} + 8} \quad (\text{empiric formula for strong sewage})$$

P = concentration, mg BOD<sub>5</sub>/ℓ

R = retention time, d

Table 7.4.1.1 Sizing of oxidation ponds

Pop. density cap/ha	1) Hydraulic loading m <sup>3</sup> /d	2) Influent BOD mg/ℓ	Total detention d	Total surface area ha	3) Surface loading BOD kg/ha
125	19600	100	6	8.3	237
200	26900	115	6.7	12.8	246
400	46400	135	7.7	25.3	249

Notes: 1) Based on DWF + I (DWF = 340 ℓ/cap, d I = 0.3 ℓ/s,ha)  
 2) Based on I = 0.3 ℓ/s,ha which is a conservative estimate  
 3) For comparison, surface loadings that are usually recommended are 150 - 350 kg BOD/ha /19/




Figure 7.4.1.1 Principle layout for oxidation pond design

#### 7.4.2 Pond construction and cost

Primary and secondary ponds are operated separately in parallel, with a typical pond size of 100 x 200 m or 2 ha; cf. figure 7.4.2.1 below.




Figure 7.4.2.1 Oxidation pond, typical section

Table 7.4.2.1 Cost estimate for 1 oxidation pond of 2 ha

Excavation, 15000 m <sup>3</sup> :	\$ 22500
Excavation, backfill and compact, 15000 m <sup>3</sup> , \$ 2.2/m <sup>3</sup>	\$ 33000
Lining (clay or polyeth.), 20000 m <sup>2</sup> , \$ 0.5/m <sup>2</sup>	\$ 10000
Slabs at water level, 364 m <sup>2</sup> , \$ 10/m <sup>2</sup>	\$ 3700
In- & outlet works	\$ 1000
Fencing, 300 m at \$ 15/m	\$ 4500
Total	\$ 74700
Construction cost of oxidation ponds is per ha	\$ <u>38000</u>

Prices for miscellaneous civil works are found in chapter 16, appendix I, table AI.3.

Table 7.4.2.2: Cost of sewage treatment, FS system, 1000 \$

Pop density cap/ha	Pond area ha	INVESTMENT			O & M	
		1) 30 years	10 years	2) after 10 yrs.	3) supplies	labour
125	8.3	316	10	158	1	12
200	12.8	486	10	243	1	13
400	25.3	960	15	480	1	17

Notes:

- 1) Comminuters at plant inlet
- 2) Pond dredging at 50% of construction cost
- 3) 4 foremen, \$ 1200/yr.  
8 labourers, \$ 600/yr.

Site upkeep 1 labourer per 2 ha pond.

7.5 Base design cost

Based on the cost estimates presented in the preceding

sections of this chapter a summary can now be made of costs for a base design. The summary appears from tables 7.5.1 - 2 and figure 7.5.1.

Table 7.5.1 Summary of cost of FS base design, 1000 \$

Density cap/ha		INVESTMENT				O & M	
		30 yr.life	10 yr.	5 yr.	after 10 yrs.	Annual supplies	labour
125	PI	2300	-	-	-	-	-
	C	6262	-	-	-	1	2
	T	316	10	-	158	1	12
200	PI	2300	-	-	-	-	-
	C	6327	-	-	-	1	2
	T	486	10	-	243	1	13
400	PI	2300	-	-	-	-	-
	C	6525	-	-	-	1	2
	T	960	15	-	480	1	17

Table 7.5.2 Preliminary PV of FS, base design

Density cap/ha		0 %		15%	
		Invest	O&M	Invest	O&M
125	PI	2300		2300	
	C	6262	90	6262	19
	T	346	706	329	134
	SUBTOT.	8908	796	8891	153
	TOT.		9704		9044
200	PI	2300		2300	
	C	6327	90	6327	19
	T	516	906	499	167
	SUBTOT.	9143	996	9126	186
	TOT.		10139		9312
400	PI	2300		2300	
	C	6525	90	6525	19
	T	1005	1500	980	267
	SUBTOT.	1590		9805	286
	TOT.		11420		10091





Figure 7.5.1

Major FS cost components (PV) preliminary analyses, cf. table 7.5.2

7.6 Cost sensitivity to level of water consumption.

The system has been redesigned for lower levels of water consumption 250 l/p,d and 125 l/p,d

At the lower flows the trunk sewer system will require slightly more maintenance. Trunk sewers amount to 13 km.

Table 7.6.1 Cost elements of FS system at decreased flows

Water cons. l/p,d	Density p/ha	1)	1)	Trunk sewers \$ 1000	Man- holes \$ 1000	Sewers total \$ 1000
		Laterals \$ 1000	Main sewers \$ 1000			
250	125	1486	2481	1120	1119	6214
	200	1486	2489	1167	1120	6262
	400	1486	2489	1230	1122	6327
125	125	1486	2489	1100	1118	6193
	200	1486	2489	1120	1119	6214
	400	1486	2489	1167	1120	6262

Notes: 1) Laterals and mains are restricted by min. sizes  
 ø 150 mm and ø 200 mm respectively

These can be routinely flushed twice a year with jet cleaning equipment within the minimum maintenance budget of \$ 3000/year.

It appears from figure 7.6.1 that the total cost, PV, of a sewerage project is virtually insensitive to the level of water consumption for which it is designed. This is because mainly the larger trunk sewers and to a minor extent the sewage treatment works are influenced by the design flow, and these components are not the primary contributors to the total project cost (figure 7.5.1)

Table 7.6.2 Sizing of oxidation ponds at decreased flow

Waste water l/p,d	Density p/ha	Hydraulic load m <sup>3</sup> /d	Influent quality BOD mg/l	1)	Total pond surface ha	Cost of pond \$ 1000
				Total pond detention d		
250	125	12105	165	9.0	7.7	292
	200	16615	190	10.0	11.8	450
	400	28660	220	11.2	22.8	866
125	125	6050	325	14.8	6.4	244
	200	8310	380	16.7	9.9	374
	400	14330	440	18.8	19.1	728

Note: 1) For design criteria and procedure see section 7.4




Figure 7.6.1 FS cost sensitivity to level of water consumption. Total cost (PV at  $i = 0\%$ ) is based on a 30 year life time, cf. tables 7.5.2 & 7.6.3

Table 7.6.3 Cost elements of FS at decreased flow

Waste water l/p,d	Density p/ha	INVESTMENT, \$ 1000		O & M, \$ 1000		
		1) 30 yrs.	2) 10 yrs.	3) after 10 yrs.	annual supplies labour	
250	125	8806	8	146	2	14
	200	9012	10	225	2	15
	400	9493	10	433	2	18
125	125	8737	5	122	2	13
	200	8888	8	187	2	14
	400	9290	10	364	2	17

Notes: 1) House installations + sewers and oxidation ponds.  
 2) Comminutors at inlet to treatment works.  
 3) Dredging of oxidation ponds after 10 years operation at 50% of construction cost.  
 4) Sewer maintenance (1+2) = \$ 3000.  
 Maintenance on treatment works: 4 foremen at \$ 1200/yr., 8 labourers at \$ 600/yr.  
 Site upkeep: 1 labourer per 2 ha pond  
 Supplies : \$ 1000/yr.

## 7.7 Cost sensitivity to slope of sewer lines

It appears from figure 7.5.1 that sewer installations constitute the major portion of the project cost. This could potentially be decreased by designing sewerlines at smaller gradients. (Tables 7.7.1, 7.7.2 and 7.7.3)

### Laterals:

Slopes of less than the recommended 20 pm are not desirable because frequent blockings, insufficient earth cover or complications with the storm ditches may result.

### Main sewers:

A potential decrease in the required min. slope for mains of 15 pm would effect requirements for higher levels of maintenance. At very small slopes a routine cleaning should be done several times per year. South African experience with similar sewer districts suggests that jet cleaning once a year is adequate to maintain small sewers laid at 4 pm slope.

### Trunk sewers:

Minimum slopes for large trunk sewers are in the range of 0.5 - 1.0% Very small savings, if any, can be generated by decreasing the slopes to such low values. (see tables 7.3.6.2 - 5).

Figure 7.7.1 summarizes the tables and demonstrates that slope of main sewers is a key factor in estimating the total cost of sewerage.



Table 7.7.1 Design of FS main sewers at small slopes

1) Slope	2) Design flow ℓ/s	3) Capacity of main sewer ℓ/s	4) Velocity at 2 x DWF m/s	5) $\tau$ at 2 x DWF kg/m <sup>2</sup>	6) Level of maintenance
2 pm	5.4	15	0.25	0.07	Regular routine basis Occasional cleaning by contractor
4 pm	5.4	22	0.3	0.13	
8 pm	5.4	30	0.4	0.21	
15 pm	5.4	41	0.45	0.32	

- Notes: 1) Based on 200 cap/ha and DWF = 340 ℓ/s, ha  
 2) Based on 5 DWF + I and 1.25 ha per main.  
 (I = 0.3 ℓ/s, ha)  
 3) Diameter 200 mm  
 4) Velocity in the lower end of main sewer  
 5)  $\tau = \gamma RI$ , see section 7. For the recommended range for  $\tau$  to ensure self cleaning at 0.15 - 0.25 kg/m<sup>2</sup> and similarly for the velocity 0.45 - 0.6 m/s  
 6) The regular maintenance should be ensured for 4 pm slope and probably even for 8 pm slope if the level of water consumption is significantly lower than assumed 400 ℓ/cap,d.

Table 7.7.2 Cost components of FS at varying gradients

Slope	Laterals		Mains		Trunk		Man-holes \$1000	Sewers total \$1000	Maintenance
	depth m	cost \$1000	depth m	cost \$1000	depth m	cost \$1000			
2 o/oo	1.1	605	1.3	810	1.5	388	738	2541	1 truck
4 o/oo	1.3	715	1.5	984	2.0	482	849	3030	1 truck
8 o/oo	1.5	825	2.0	1390	3.0	743	988	3946	occasional
15 o/oo	2.5	1486	3.0	2489	5.0	1230	1122	6327	onal

- Notes: Prices from appendix I, chapter 16  
 Estimates are made for 200 p/ha and DWF=340 ℓ/p,d

Table 7.7.3 Total cost components of FS at small slopes

Slope pm	INVESTMENT			O&M		
	1) 30 year	1) 10 year	2) 5 year	1) After 10 year	2) Annual supplies	Annual labour
2	5327	10	30	243	3	17
4	5816	10	15	243	2	15
8	6732	10	-	243	2	15
15	9113	10	-	243	2	15

- Notes: 1) Cost of sewage treatment from table 7.4.2.2  
Cost of house installations from table 7.2.1
- 2) One jet cleaning truck can service an estimated 600 m sewer per day. Based on 200 effective working days, per year a total of 120 km sewer line can be cleaned i.e. all main and trunk sewers can be cleaned twice a year with one jet cleaning unit in operation. It is estimated that 2 cleanings per year is adequate for 4 pm slope, whereas 2 units are recommended for 2 pm to increase the cleaning frequency and to ensure operation in case of a long term breakdown. Price per unit is (lifetime 5 years):
- |             |   |
|-------------|---|
| Vehicle     | \$ 10000 + 50% for spare parts          |
| Supplies    | \$ 0.7 per operating hour:<br>\$ 1400/y |
| 1 driver    | \$ 1000/y                               |
| 2 labourers | \$ 600/y                                |

## 7.8 Cost sensitivity to slope of land

In the case of flat land conditions extra expenses are incurred due to increased investments that result from deep excavations and due to increased pumping of sewage.

In the previous sections a natural land slope of 3 pm was assumed. An estimate of the economical impact of other land slopes can be made using data that are already developed.

### 7.8.1 Pumping

In situations with no natural slope of the area, the re-




Figure 7.7.1

FS cost sensitivity to slope of main sewers. PV as based on 200 p/ha DWF = 340 l/p,d; i = 0%, and time horizon = 30 y; cf. cost data table 7.7.3

quired gradients of mains would greatly influence the amount of pumping. The trunk gradients would influence the total cost to a very limited extent (section 7.7). The necessary lift of sewage can be estimated from table 7.7.2 assuming that all sewage is collected by gravity down to the treatment plant and then pumped up in one operation (which is possibly not the most economical solution to the sewerage design, because deep excavation is relatively expensive, but it does give a fair estimate of total pumping cost involved). Using these data table 7.8.1.1 can be established.

Comparing the figures in table 7.8.1.1 with those in table 7.7.3 and figure 7.7.1 it appears that pumping costs will be negligible. The order of magnitude will be 2 - 3% of

Table 7.8.1.1 FS pumping of sewage for different gradients of mains, 1000 \$/y

<u>Density</u> <u>cap/ha</u>	<u>Flow</u> <u>m<sup>3</sup>/d</u>	<u>Mains' gradients &amp; pumping lift, pm &amp; m</u>		
		<u>4&amp;2.5</u>	<u>8&amp;4</u>	<u>15&amp;7</u>
125	19600	3.0	4.8	8.3
200	26900	4.1	6.5	11.5
400	46400	7.1	11.3	19.8

Notes: Sewage 340 l/p,d  
 Infiltration .3 l/s,ha  
 Power .04 \$/kWh  
 Efficiency .6  
 The lift indicated is based on the average trunk depth, cf. table 7.7.2, + compensation for trunk slope and head loss through treatment plant.

total project cost for slope of mains in the range of 4 to 15 pm.

Tables 7.7.2 and 7.7.3 were established under the assumption that land slope averages 3 pm. It is now realized that changes of mains' gradients in the interval of 8 - 15 pm do not significantly change the fact that pumping costs are negligible in the context of total present value of sewerage. Consequently, in terms of pumping it would have no essential economical effect whether land slope changes from 3 pm to 0 pm. If land slope become greater than 3 pm the pumping expenses approach Zero and become even less important.

Pumping was not included in the previous cost sensitivity analysis, and this simplification seems justified.

### 7.8.2 Escavation

Escavation costs are of greatest importance to sewerage investment and total cost. This is particularly true for

flat land and high ground water level. Further, it was realized in section 7.7 that cost is especially sensitive to gradients of main sewers.

Therefore, if the land slope exceeds that required for main sewers there would be possibilities for savings in the order of magnitude of 35% as demonstrated on figure 7.7.1. The reference used for figure 7.7.1 is a land slope of 3% but this does not significantly change the fact demonstrated, namely that great slope requirements become very costly (due to excavation) unless the land as such offers the necessary slope.

Deep excavation could be avoided by installation of pumping stations which is common practice in areas with flat slope. Savings in excavation are then counteracted by extra expenses for installation and maintenance of pumping stations though possibly with a net saving with present prices on energy supply. This consideration will not be carried further in the present report.

The conclusion is that land slope available should be compared to main sewer slope requirements. A price difference of 30 - 50% might easily be realized when comparing sewerage at a gently sloping to a flat development area.

#### 7.9. Cost effects of road pavement

If a sewer project should be installed in an existing city the price of sewer construction would include extensive road repair. In order to appreciate the magnitude of this potential extra cost a rough estimate has been developed below.

The price of removing and replacing pavement is estimated to \$ 37/m sewer, /23/.

If the main sewers are placed in roads, rather than on the private plots the potential extra expenditure is:

100000 at \$ 37/m = \$ 3.7 x 10<sup>6</sup> which represents approximately 40% of the project cost.

If the main sewers are placed off the roads where possible the total length of sewerline in roads is only 40000 m which represents \$ 1.5 x 10<sup>6</sup> or 15% of the project cost.

7.10. Preliminary FS evaluations

In order to compare the full sewerage alternative to other alternatives (chap. 8 - 11) the following representative parameters have been chosen:

- Water consumption 250 l/cap x day
- Average gradient of main sewers 8 pm
- Average slope of area 3 pm

Data are extracted from tables in the preceding chapters and summarized in tables 7.10.1 & 2 below.

Table 7.10.1 Cost components of FS system

	1)	2)	3)			4)
Density	Laterals	Main sewers	Trunk sewers	Manholes	Total sewer	Mainten-
cap/ha	\$ 1000	\$ 1000	\$ 1000	\$ 1000	\$ 1000	ance
125	825	1390	677	988	3880	Regular
200	825	1390	705	988	3908	mainten-
400	825	1390	743	988	3946	ance, 1 truck

- Notes:
- 1) Average depth for laterals 1.5 m
  - 2) Average depth for mains 2.0 m
  - 3) Average depth for trunks 3.0 m
  - 4) Routine maintenance is preferred rather than the services of a contractor, because the waste flow may not be as high as assumed in the design.

Table 7.10.2 Summary of the cost of FS

Density cap/ha	INVESTMENT, \$ 1000			O&M, \$ 1000		
	3o yr.	1o yr.	5 yr.	After 1o yr.	Annual	
					supplies	labour
125	PI	2300				
	C	3880		15	1	2
	T	292	8		146	1
200	PI	2300				
	C	3908		15	1	2
	T	450	8		225	1
400	PI	2300				
	C	3946		15	1	2
	T	866	10		433	1

Table 7.10.3 PV for FS, 1000 \$

Density cap/ha		0%		5%		15%	
		Inv.	O&M	Inv.	O&M	Inv.	O&M
125	PI	2300	-	2300	-	2300	-
	C	3970	90	3933	46	3909	20
	T	316	682	308	201	302	131
	SUBTOT.	6586	772	6541	247	6511	151
	TOT.		7358		6788		6662
200	PI	2300	-	2300	-	2300	-
	C	3998	90	3961	46	3937	20
	T	474	870	466	438	460	162
	SUBTOT.	6772	960	6727	484	6697	182
	TOT.		7732		7211		6879
400	PI	2300	-	2300	-	2300	-
	C	4036	90	3999	46	3975	20
	T	896	1376	886	690	879	246
	SUBTOT.	7232	1466	7185	736	7154	266
	TOT.		8698		7921		7420

Table 7.10.4 FS annual O&M, labour employment

Density <u>cap/ha</u>	Labourers employed <u>no</u>	Cost	
		<u>supplies</u> \$ 1000	<u>wages</u> \$ 1000
125	19	2	14
200	21	2	15
400	26	2	18

Table 7.10.5 PV per capita for FS, \$ total

Density <u>cap/ha</u>	0%		5%		15%	
	<u>Tot.</u>	<u>O&amp;M</u>	<u>Tot.</u>	<u>O&amp;M</u>	<u>Tot.</u>	<u>O&amp;M</u>
125	210	22	194	7	190	4
200	138	17	129	9	123	3
400	76	13	69	6	65	2

Table 7.10.6 FS user charge, 30 years, \$/y

Density <u>cap/ha</u>	0%		5%		15%	
	<u>plot</u>	<u>cap.</u>	<u>plot</u>	<u>cap.</u>	<u>plot</u>	<u>cap.</u>
125	22	7	39	13	90	30
200	23	5	42	8	93	19
400	26	3	46	5	100	10

Note: Figures are derived from table 7.10.3 totals using the criteria developed in chapter 6






Figure 7.10.1

Differentiated cost of FS, PV results for 30 y planning horizon. Cf. table 7.10.3




Figure 7.10.2 FS, accumulated total cash flow at  $i = 0\%$

## 8. AQUA PRIVY WITH PIPED LIQUID DISPOSAL

### 8.1. Design considerations

This scheme proposes that the toilet buildings for 4 plots are located adjacently as shown on figure 8.1.1 below. Thereby the need for laterals has been eliminated. A settling tank is installed underneath each toilet module to allow the sewer system that receive the overflow to be designed with a very small gradient. Latrine waste, sink waste water, shower water and kitchen waste water is led to the tank. The combination of shower and toilet slab in the same privy compartment would be a convenient option for the plot owner. This combination of toilet & shower is being used for example in Thailand. The tank accumulates settleable solids, whereas the supernatant overflows to the sewer. The mean solids residence time is 1 - 3 month, so considerable anaerobic microbial liquefaction of organic solids will take place. The sludge is collected by vacuum truck on a regular service basis e.g. biannual emptying and disposed into the primary ponds at the treatment works. Needless to say, the success of this scheme depends on the ability of the local authority to operate the maintenance scheme.

### 8.2. Plot installation, design & cost

The sludge accumulation in privies may be estimated as follows:

Settleable suspended solids = 90 g/cap,d                    /22/

Microbial activity effects 50% solids reduction.

The annual sludge accumulation (6% solids) is then  
 $0.5 \times 90 \times 1/1000 \times 365 \times 100/6 = 275 \text{ l/cap,y.}$

The hydraulic detention time is in excess of 24 hrs.

Cost estimations are then carried out in the following tables  
8.2.1 & 8.2.2.




Figure 8.1.1 Aqua privy, details and plot situation

### 8.3. Sewage collection

The collection "main" sewer line is aligned alongside the row of toilet buildings and the privy overflow connects to the sewer with a 45° junction piece; figure 8.1.1.

The privies will retain sand and heavy organic material thus only a minimum maintenance will be required for sewers in spite of the low gradient (4 pm). In this alternative it is

Table 8.2.1 Design of aqua privy

Density	1) cap/ha	2) Empty- ing no/mo	3) Estim. sludge accum. m <sup>3</sup>	3) Required tank volume m <sup>3</sup>	4) Cost per unit \$	5) Cost of add. sink \$
125	12	6	1.7	4.5	450	50
200	20	4	1.8	4.5	450	50
400	40	2	1.8	4.5	450	50

- Notes: 1) 10 aqua privy units per ha (one per 4 plots)  
 2) Tanker truck capacity 2.0 m<sup>3</sup>  
 3) Liquid volume 4.0 m<sup>3</sup>, see design figure 8.1.1  
 4) Cost includes tank, cover slab with 4 CM squatting plates, connection to the main sewer and a 4 m tall vent stack. A shower head is located in each stall but the price of this installation is exclusive.  
 5) A sink for washing clothes and utensils is installed, and the drain led to the privy tank.

Table 8.2.2 Maintenance of Privies

Density	1) Emptyings	2) Trucks required	3) Cost of trucks 5 yr life \$ 1000	Annual O&M	
	No/y	No	\$ 1000	4) Supplies \$ 1000	5) Labour \$ 1000
125	5600	4	60	4	9
200	8400	6	90	7	13
400	16000	12	180	14	26

- Notes: 1) Based on a total of 2800 aqua privies  
 2) 1 privy emptying per truck load.  
 7 privies serviced per 8 hour day. (1 hour round trip per privy visit and 1 hour start up and close down).  
 250 working days per year less 20% for breakdown and service. I.e. 1400 privy services per truck per year.  
 3) Price of one truck is \$ 10000 + 50% for spare parts during the 5 year lifetime.  
 4) Supplies for trucks is \$ 0.7 per operating hour  
 5) Per truck 1 Driver 1000 \$/y  
 2 Labourers 1200 \$/y

Table 8.3.1 Design of AP main sewers

Population density cap/ha	1) Design flow	Required diameter mm	Capacity at a slope of 4 ‰	2) Sewer maintenance
	ℓ/sec		ℓ/sec	
125	1.2	100	3.5	minimum
200	1.8	100	3.5	-
400	3.3	150	10	-

Notes: 1) 5 DWF + I based on a wasteflow of DWF og 105 ℓ/cap x day and infiltration I = 0.3 ℓ/sec, ha and a maximum drainage area of 1.25 ha.  
2) Cleaning of occational blockings by a contractor.

Table 8.3.2 Cost of AP sewage collection

Population density cap/ha	Cost of			3) Total sewerage \$ 1000	4) O&M annual	
	1) mains \$ 1000	2) trunks \$ 1000	manholes \$ 1000		supplies \$ 1000	labour \$ 1000
125	695	460	350	1505	1	2
200	695	460	350	1505	1	2
400	868	470	350	1688	1	2

Notes: 1) Total length of main sewers 57890 m.  
Slope 4 ‰ i.e. average depth 1.5 m at \$ 12/m for Ø 100 mm and \$ 15/m for Ø 150 mm  
2) Average depth 2.0 m  
3) 30 y lifetime  
4) Cleaning of occational blockings

imperative that plastic pipes are used for sewers to avoid corrosion damages. Should future development require that toilets are transferred into the houses, then the system can be adapted to this situation. Flush toilets are easily connected to the privy. (The tank can also easily be converted to a regular manhole should future increased inflow favourize a regular sewer system rather than an aqua privy system. In this latter case considerable sewer maintenance would be required in the light of the flat slope at which the collecting sewer is designed, and generally this modification may not be possible without changing the piped network drastically.

#### 8.4. Sewage treatment facilities

Sewage treatment is carried out in a system of facultative oxidation ponds. The sludge that has been collected from the tanks is to be disposed into the primary ponds. No net BOD reduction is taken into account from the short retention in the tanks because the organic acids - that are formed from microbial liquefaction of organic solids in the tank - will not be degraded to any large extent until the liquid phase reaches the treatment ponds.

Design and cost considerations appear from table 8.4.1

#### 8.5. Preliminary AP evaluation

Basic data for further comparison between AP and other systems are presented in tables 8.5.1 - 5 and figures 8.5.1 & 2.

Table 8.4.1 Design and cost of oxidation ponds for AP

Population density <u>cap/ha</u>	1)	2)	Total deten- tion <u>d</u>	Pond area <u>ha</u>	3)	4)	5)	6)	
	Hydr. load <u>m<sup>3</sup>/day</u>	Infl. qual. BOD <u>mg/ℓ</u>			Cost of ponds <u>\$ 1000</u>	Cost of station. equipm. <u>\$ 1000</u>	10 yr. O&M <u>\$ 1000</u>	<u>Annual O&amp;M</u> supplies labour <u>\$ 1000</u> <u>\$ 1000</u>	
125	7471	265	12.8	6.8	258	10	129	1	11
200	9726	325	14.9	10.3	392	10	196	1	12
400	15741	400	17.6	19.6	745	15	372	1	16

- Notes:
- 1) Waste flow = 105 ℓ/cap x day + infiltration I = 0.15 ℓ/sec, ha
  - 2) The collected sludge is disposed into the primary ponds, so the organic load is 55 g BOD/cap,d (see chapter 7)
  - 3) Based on \$ 38000 per ha pond (chapter 7)
  - 4) Equipment for sludge disposal and truck cleaning, 10 year lifetime is assumed.
  - 5) Dredging of ponds after 10 years of operation (50% of construction cost)
  - 6) 4 foremen at \$ 1200/y  
8 labourers at \$ 600/y  
Site upkeep 1 labourer at \$ 600/2 ha pond



Table 8.5.1 Summary of AP cost components

Density cap/ha	Cost item	INVESTMENT, \$ 1000			O&M, \$ 1000		
		3o y.	1o y.	5 y.	after 1o y.	annual supplies	labour
125	PI	1400					
	1) C	1505		60		5	11
	T	258	10		129	1	11
200	PI	1400					
	C	1505		90		8	15
	T	392	10		196	1	12
400	PI	1400					
	C	1688		180		15	28
	T	745	15		372	1	16

Note: 1) Sewers + sewer and privy maintenance.

Table 8.5.2 PV of AP system, 1000 \$

Density cap/ha	Cost item	i = 0%		i = 5%		i = 15%	
		Invest \$ 1000	O&M \$ 1000	Invest \$ 1000	O&M \$ 1000	Invest \$ 1000	O&M \$ 1000
125	PI	1400	-	1400	-	1400	-
	C	1865	480	1718	246	1623	105
	T	288	618	278	312	271	119
	SUBTOTAL	3553	1098	3396	558	3294	224
	TOTAL	4651		3954		3518	
200	PI	1400	-	1400	-	1400	-
	C	2045	690	1825	354	1681	-
	T	422	782	412	394	405	146
	SUBTOTAL	3867	1472	3637	748	3486	297
	TOTAL	5339		4385		3783	
400	PI	1400	-	1400	-	1400	-
	C	2768	1290	2327	661	2041	283
	T	790	1255	775	630	765	227
	SUBTOTAL	4958	2545	4502	1291	4206	510
	TOTAL	7503		5793		4716	

Table 8.5.3 Annual O&M, labour employment for AP

Density cap/ha	Labourers employed No.	Cost	
		Supplies \$ 1000	Wages \$ 1000
125	16	6	22
200	18	9	27
400	23	16	44

Table 8.5.4 PV/cap for AP

Pop. density cap/ha	i=0%		i=5%		i=15%	
	Tot	O&M	Tot	O&M	Tot	O&M
125	133	31	113	16	101	6
200	95	26	78	13	68	5
400	66	22	51	11	41	4

Table 8.5.5 User charge for AP

Pop. density cap/ha	i=0%		i=5%		i=15%	
	plot	cap	plot	cap	plot	cap
125	14	5	23	7	47	16
200	16	3	25	5	51	10
400	22	2	33	3	64	6

Note: Figures are derived from table 8.5.2 using criteria from chapter 6 concerning constant annual expenditures for users




Figure 8.5.1

Differentiated total PV for the AP system 30 y planning horizon, cf. table 8.5.2




Figure 8.5.2

Accumulated total cash flow for AP  
at  $i = 0\%$

## 9. HOUSE VAULT & VACUUM TRUCK

### 9.1. Design & components

Basically the system consists of a house tank which is used for accumulation of only excreta from the users and which is emptied regularly by a vacuum truck, e.g. every 2 weeks. There are two modifications, cf. figure 9.1.1.

- a) Chiang Mai Squatting Plate with siphon, i.e. a water seal between privy and vault. The flush is manual and demands little water, e.g. 0.8 l/visit.
- b) Japanese Stool with only a vertical chute between privy and vault. No flushing is applied.

Two families (plots) are supposed to share the same vault, but each family has its own privy above the vault.

These systems do not include disposal of wash water (grey waste), which is presumed disposed indiscriminately or into the storm water system.

### 9.2. Vaults

Information is given on vault capacities & costs in table 9.2.1. Based on the information in table 9.2.1 the price for vaults and basic privy installation is then summarized in table 9.2.2.

### 9.3. Vacuum trucks, Crews and Service areas

Truck prices are found in table 6.5.3.1. According to Japanese practice the 2 m<sup>3</sup> tank (1.8 m<sup>3</sup> normally used in Tokyo and suburbs) is the preferable one; it is very flexible in traffic and it does not require heavy duty pavement. The 2 m<sup>3</sup> tank will be used in subsequent calculations.




Figure 9.1.1 Plot & privy lay-out for JS & CM systems

The calculation of collection costs is indicated in table 9.3.2 and basic data are found in chapter 6.

#### 9.4. Treatment ponds

Treatment of night soil from vaults will be done in oxidation

Table 9.2.1 JS & CM vault capacities and costs

System	Density cap/ha	3)	4) Accul. vol.		5)	6)	Cost \$
		Cap/vault no	2w m <sup>3</sup>	3w m <sup>3</sup>	Depth m	Diam. m	
JS	1) 125	6	.12	.18	.7	.6	100
	200	10	.20	.30	1.1	.6	130
	400	20	.40	.60	1.2	.8	100
CM	2) 125	6	.6	.9	1.2	1.0	150
	200	10	1.0	1.5	1.3	1.2	200
	400	20	2.0	3.0	1.7	1.5	300

- Notes: 1) 1.4 liter/cap,d cf KAWASAKI /24/ and PRA /25/  
 2) 1.4 liter/cap,d + .8 l flushing water/visit;  
 7 visits/day = 1.4 + 5.6 = 7 l/cap,d  
 3) 2 families per vault  
 4) Collection every 2 or 3 weeks. Vault design for 3 weeks storage. Truck design for 2 weeks accumulation.  
 5) Depth of vault = necessary depth for storage during 3 weeks (50% margin with respect to emptying). Slab 0.1 meter above ground to avoid surface water infiltration.  
 6) Prices are estimated from chapter 7: Full sewerage. The cost includes stool or squatting plate but not superstructure for the privy.

Table 9.2.2 JS & CM, plot development costs, vaults & slabs.

System	Density cap/ha	Vaults/ha no	Cost/ha \$	Total 1000 \$
JS	125	20	2000	573
	200	20	2600	745
	400	20	3600	1031
CM	125	20	3000	859
	200	20	4000	1146
	400	20	6000	1718

Note: Total area = 286.4 ha

Table 9.3.1 Number of trucks necessary for JS & CM

System	Cap/ ha	1) Vaults per full truck	2) 3) Round trips	2) Vaults per 2 w per truck	4) Area served by one truck ha/2w	5) Trucks & crews
	no	no	no/d	no	ha/2w	no
JS	125	17	1+	260	13	26
	200	10	2+	230	11.5	30
	400	5	4	200	10	34
CM	125	3	5	150	7.5	46
	200	2	6	120	6	57
	400	1	8	80	4	86

- Notes: 1) cf. table 9.2.1, 2 week's accumulation  
 2) 2 weeks = 10 days of 8 hours = 80 hours  
 1 service necessary each 2 weeks = min. reg.  
 Vault service = 15 min including travel between  
 two sites- Truck emptying = 45 min., including  
 round trip. Start up and close down = 45 min.  
 including travel to first and from last vault.  
 The garage is located adjacent to the empt. station.  
 3) A truck is not necessarily full when returning  
 last time during the day. This is accounted for  
 in the number of vaults emptied and hectares  
 served. In an actual situation the sizing and  
 routing of trucks would be done through a simple  
 operation research procedure. This would yield  
 an optimal solution, whereby the area served would  
 be greater than or equal to the one indicated  
 above. A more detailed and refined approach is  
 not justified at this preliminary stage of anal-  
 ysis.  
 4) 20 vaults/ha  
 5) Indicated in this column is the theoretically  
 necessary number + 20% in order to give time  
 for maintenance and repair (1 day out of each  
 week). Also crews mechanics, shop labour etc  
 are increased accordingly. Total area 286.4 ha.






Figure 9.3.1

Vacuum truck. Used in Tokyo and suburbs for night soil collection. 1.8 m<sup>3</sup> tank capacity is very common. Courtesy: Tokyu Car Man. Co

ponds as proposed by SHAW /26/, who found that for a pond loading of 3000 cap/ha and under South African climatic conditions the pond will function satisfactorily. Make-up water may be necessary depending on precipitation/evaporation ratios in which case no effluents will appear. Pumping will be required for proper stirring and mixing in the pond during discharge of new soil.

The ponds proposed in chapter 7 have a surface loading of app. 4500 persons/ha, i.e. somewhat higher than proposed by SHAW for night soil treatment under South African conditions. There is no information available to compare these loading rates under tropical conditions, but it is assumed for the present that previous calculations (chapter 7) apply also to night soil ponds. Maintenance and operation routines are assumed to be more labour demanding; an estimated 100% increase of O&M is used in subsequent calculations.

Table 9.3.2 Collection costs, trucks & labour  
for JS & CM systems

System	Density <u>cap/ha</u>	1)	2)	3)	<u>Operation &amp; Mainten.</u>		
		Trucks & crews <u>no</u>	Garages repair shops <u>1000\$</u>	Truck purch. & parts <u>1000\$</u>	4) Gas oil tires <u>1000\$</u>	5) Crew <u>1000\$</u>	Total annual O&M <u>1000\$</u>
JS	125	26	13	390	38	42	80
	200	30	15	450	44	48	92
	400	34	17	510	50	54	104
CM	125	46	23	690	67	74	141
	200	57	29	855	83	91	174
	400	86	43	1290	125	138	263

- Notes:
- 1) A crew consists of 1 driver and 1 labourer.  
Wages are found in table 6.5.2.1  
Truck numbers from table 9.3.1
  - 2) Repair shops (shelters) and parking facilities  
are estimated at a total price of 10 \$/m<sup>2</sup> and  
a need of 50 m<sup>2</sup>/truck.  
Life time is estimated at 10 years.
  - 3) Trucks have an estimated life-time of 5 years.  
50% has been added to the purchase price in order  
to make up for spare parts.
  - 4) .7 \$/hour of operation. 80 hours operation in  
2 weeks gives app. 2100 hours/year, truck.
  - 5) Ref. table 9.3.3. Also, note 5) in table 9.3.1  
as to safety with truck and crew numbers.

### 9.5. Preliminary JS & CM evaluations

An economic evaluation of the night soil systems JS and CM  
is presented in tables 9.5.1 & 2.

Table 9.4.1 Night soil treatment costs for JS & CM systems

System	Density cap/ha	1) Total pond surface ha	Invest, 1000 \$		O & M, 1000 \$	
			ponds 30 y life	pumps 10 y life	2) annual	3) each 10 y
JS	125	8	310	20	26+1	160
&	200	13	490	30	28+2	240
CM	400	25	950	40	36+4	480

Notes: 1) Cf. table 7.5.4; 4500 persons/ha pond  
 2) O & M is estimated to be twice the annual cost for sewage treatment, cf. table 7.5.4. Cost for extra pumping is added for cleaning of tanks, loading apron etc. Continuous agitation of ponds is not considered necessary.

Table 9.5.3 Employment and annual O&M for JS & CM

System	Density cap/ha	Labour employed no	Trucks used no	Cost	
				Suppl. 1000 \$	Wages 1000 \$
JS	125	84	26	39	68
	200	97	30	46	76
	400	117	34	54	90
CM	125	124	46	68	100
	200	151	57	85	119
	400	221	86	129	174

Note: 10-year pond remodeling is not included in O&M

Density	System	Cost item 1) 2)	Actual costs, 1000 \$, 1975 \$ & prices					Total PV in 1000 \$		
			Vaults ponds	Stat. equipm.	Mobile equipm.	O&M	30 year planning horizon given interest rate of			
cap/ha			30 y life	10 y life	5 y life	annual	each 10 y	0%	5%	15%
125	JS	PI	573	0	0	0	0	573	573	573
		C	0	13	390	80	0	4779	2641	1307
		T	310	20	0	27	160	1500	923	563
	Total		883	33	390	107	160	6852	4137	2443
	CM	PI	859	0	0	0	0	859	859	859
		C	0	23	690	141	0	8439	4663	2308
T		310	20	0	27	160	1500	923	563	
Total		1169	43	690	168	160	10798	6445	3730	
200	JS	PI	745	0	0	0	0	745	745	745
		C	0	15	450	92	0	5505	3042	1506
		T	490	30	0	30	240	1960	1449	800
	Total		1235	45	450	122	240	8210	5236	3051
	CM	PI	1146	0	0	0	0	1146	1146	1146
		C	0	29	855	174	0	10437	5767	2857
T		490	30	0	30	240	1960	1449	800	
Total		1636	59	855	204	240	13543	8362	4803	
400	JS	PI	1031	0	0	0	0	1031	1031	1031
		C	0	17	510	104	0	6231	3443	1705
		T	950	40	0	40	480	3230	2120	1434
	Total		1981	57	510	144	480	10492	6594	4170
	CM	PI	1718	0	0	0	0	1718	1718	1718
		C	0	43	1290	263	0	15759	8708	4312
T		950	40	0	40	480	3230	2120	1434	
Total		2668	83	1290	303	480	20707	2546	7464	

Notes: 1) Plot development includes vault & slab, not superstructure  
 2) Treatment does not include outfall constructions.

Table 9.5.4 PV for CM and JS systems

System	Density cap/ha	0%		5%		15%	
		Tot.	O&M	Tot.	O&M	Tot.	O&M
JS	125	196	101	118	52	70	22
	200	147	74	94	38	54	16
	400	92	46	58	24	37	10
CM	125	309	153	184	78	107	33
	200	242	118	149	60	86	25
	400	182	88	110	45	65	19

Table 9.5.5 User and plot charges for JS & CM systems, \$/y

System	Density cap/ha	0%		5%		15%	
		plot	cap	plot	cap	plot	cap
JS	125	20	7	24	8	33	11
	200	24	5	30	6	41	8
	400	31	3	38	4	56	6
CM	125	32	11	37	12	50	17
	200	40	8	48	10	65	13
	400	61	6	72	7	101	10

Note: Values derived from figures 9.5.1 and 9.5.2 using criteria from chapter 6 concerning constant annual user expenditures.






Figure 9.5.1

PV for JS system, 30 y planning horizon, cf. table 9.5.1





Figure 9.5.2

PV for CM system, 30 y planning horizon, cf. table 9.5.2




Figure 9.5.3

Accumulated total cash flow at  $i = 0\%$   
for JS and CM systems



## 10. HOUSE BUCKET & ABLUTION BLOCK

### 10.1. Design considerations

The proposed scheme introduces the following:

1. Each house has bucket latrine. A member of the household carries the bucket to an emptying and cleaning facility at most 150 m away (in the ablution block).
2. Ablution blocks serving 500 people are built regularly spaced in the community - maximum distance from a home to the nearest ablution facility is 150 m, cf. figure 10.1.1. The blocks include stand pipes for drinking water, toilets, showers, facilities for washing clothes and utensils and an arrangement for emptying and cleaning the private latrine buckets. The whole ablution block is cleaned and maintained by full time employed attendants.
3. Individual houses are not provided with piped water or piped drainage.

In the context of this report drainage facilities alone are considered; however the superstructure for the ablution block has been included in the cost estimates, because the structure is a public facility in this design, contrary to what is the case when the toilet and washing facilities are located on the individual plots.

### 10.2. Ablution block

Tables 10.2.1 and 10.2.2 summarize the data for the ablution block system.

### 10.3. Sewage collection system

The collection system includes sewers from all ablution blocks inclusive of manhole adjacent to the buildings. Maintenance of the pipe system is included. Sewers are designed




Figure 10.1.1 House Bucket & Ablution Block, system AB, lay-out and details

for flat slopes (4 pm) and a high level of maintenance (regular cleaning). The intermittent and high water usage at the facility also provides a good condition for selfcleaning of the collection system.

Collection costs are calculated and presented in table 10.3.2.

Table 10.2.1 AB specifications

Facility	Capacity	Area	Required	Area
	cap/unit	per unit	units	per AB
	no	m <sup>2</sup>	no	m <sup>2</sup>
Toilet	50	1.5	10	15
Pissoire	250	5.	2	10
Wash places	20	2.	25	50
Showers	25	2.	20	40
Latrine disp. & bucket clean.	250	5.	2	10
<u>Extra space</u>				<u>25</u>
Total floor area required per ablation block:				150

Table 10.2.2 Cost of sanitary installations per ablation block.

Facility	INVESTMENT			O&M	
	30 yr	10 yr	5 yr	Supplies	Labour
	\$	\$	\$	\$/y	\$/y
1) Latrine bucket			1600 1000 500		
2) Slabs, drains & toilets	9000				
3) Super structure	6000				
Maintenance and cleaning				4) 500	5) 1800

Notes: 1) One bucket at \$ 10 per plot, price for the respective population densities; cf. figure 10.1.1  
 2) Includes concrete slab with drains, toilets and all internal drain pipes at \$ 60/m<sup>2</sup>  
 3) Includes concrete walls, partitions, doors and a light sheet metal roof at \$ 40/m<sup>2</sup>  
 4) Detergents & brooms  
 5) Attention 16 h/d, week and holidays  
 3 labourers at \$ 600 per year

Table 10.3.1 Design of sewers from ablution blocks

Density cap/ha	Service area per block ha	1) Spacing of sewers Ø 150 mm	2) Max. flow l/s	Pipe cap. at 4 o/oo l/s	3) Cleaning frequency per yr.
125	4	4th road	1.8	10	6-8 times
200	2.5	2nd road	1.8	10	4-6 times
400	1.25	2nd road	3.6	10	4-6 times

- Notes: 1) Minimum size to avoid blockings  
 2)  $6DWF + I$ , based on  $DWF = 50 \text{ l/p,d}$  and  $I = 0.1 \text{ l/s, ha}$ . If water is free of charge the flow is likely to increase to 75-100  $\text{l/p,d}$ . The drainage system is adequate to accommodate this flow.  
 3) One sewer-cleaning vehicle in continuous operation 200 operating days per year. One unit is estimated to service 600-900 m sewer per day.

10.4. Sewage treatment system

Facultative oxidation ponds are used for sewage treatment. Comminuters are installed at inlet works. The treated effluent is disposed into the brackish Ebute Metta Creek.

Tables 10.4.1 & 2 give data on pond design and sewage treatment.

10.5. Preliminary AB evaluations

Basic data for further comparison between AB and other systems are presented in tables 10.5.1 - 5.

Table 10.3.2 Cost of sewage collection for AB

Density cap/ha	Blocks no	Sewers from blocks		Trunk sewers 2) \$ 1000	Manholes 3) \$ 1000	Sewers total \$ 1000	Trucks 4) \$ 1000	O&M	
		1) m	\$ 1000					5) Supplies \$ 1000	6) Labour \$ 1000
125	70	10900	164	440	30	634	15	1	2
200	115	17400	261	450	42	753	15	1	2
400	230	17400	261	460	49	770	15	1	2

- Notes: 1) Ø 150 mm sewer at average depth 1.5 m at \$ 15/m  
 2) Average depth 2.0 m, min. size for trunk sewer is Ø 250 mm  
 3) 1 type I manhole at \$ 100 per block  
 1 type II manhole at \$ 300 per connection to trunksewer + 5 additional  
 4) Price of 1 sewer cleaning unit is \$ 10000 + 50% for spare parts  
 during 5 yr lifetime  
 5) Supplies are estimated to \$ 0.7 per operating hour  
 6) 1 driver at \$ 1000/y and 2 labourers at \$ 600/y, cf. chapter 6.

Table 10.4.1 Sizing of treatment ponds for AB system

Density cap/ha	1) Hydraulic load m <sup>3</sup> /day	2) Influent quality mg/l. BOD <sub>5</sub>	3) Total detention time <sub>d</sub>	Total surface area ha
125	4264	461	19.7	6
200	5338	590	24.3	10
400	8202	770	30.7	18

Notes: 1) Based on an estimated DWF = 50 l/cap,d  
+ infiltration I = 0.1 l/sec, ha  
2) Organic load 55 g BOD/cap,d (see chapter 7)  
3) Assumed min. month temperature 22°C;  
design procedure is indicated in chapter 7

Table 10.4.2 Cost of sewage treatment for AB system

Density cap/ha	INVESTMENT		O&M		
	Pond construc. 30 y life 1) \$ 1000	Comminuters 10 y life \$ 1000	10 y 2) \$ 1000	annual suppl. 3) \$ 1000	labour \$ 1000
125	228	5	114	1	10
200	380	5	190	1	11
400	684	8	342	1	13

Notes: 1) Based on \$ 38000/ha pond surface  
2) Dredging of ponds after 10 years at 50% of  
construction cost.  
3) 4 foremen at \$ 1200/y  
6 attendants at \$ 600/y  
Site upkeep 1 labourer/2 ha pond

Table 10.5.1 Cost components for AB system

Density cap/ha	Cost item	INVESTM., \$ 1000			O&M, \$ 1000		
		life 3o y	lo y	5 y	After lo y	Supplies	Labour
125	PI	1050	-	112	-	35	126
	C	634	-	15	-	1	2
	T	228	5	-	114	1	10
	TOTAL	1912	5	127	114		175
200	PI	1725	-	115	-	57	207
	C	753	-	15	-	1	2
	T	380	5	-	190	1	11
	TOTAL	2858	5	130	190		279
400	PI	3450	-	115	-	115	414
	C	770	-	15	-	1	2
	T	684	8	-	342	1	13
	TOTAL	4904	8	130	342		546

Table 10.5.2 PV for AB system, 1975 \$,  
3o y planning horizon

Density cap/ha	Cost item	i=0%		i=5%		i=15%	
		Invest \$ 1000	O&M \$ 1000	Invest \$ 1000	O&M \$ 1000	Invest \$ 1000	O&M \$ 1000
125	PI	1722	4830	1448	2475	1270	1058
	C	724	90	687	46	663	20
	T	243	558	238	282	235	108
	SUBTOT. TOTAL	2689	5478	2373	2803	2168	1186
		8167		5176		3354	
200	PI	2415	7920	2133	4058	1950	1734
	C	843	90	806	46	782	20
	T	395	740	390	373	387	138
	SUBTOT. TOTAL	3653	8750	3329	4477	3119	1892
		12403		7806		5011	
400	PI	4140	15870	3858	8131	3675	3476
	C	860	90	823	46	799	20
	T	708	1104	700	554	694	198
	SUBTOT. TOTAL	5708	17064	5381	8731	5168	3694
		22772		14112		8862	

Table 10.5.3 Annual O&M for AB system

<u>Pop. density</u> <u>cap/ha</u>	<u>Labour</u> <u>empl.</u> <u>no</u>	<u>Trucks</u> <u>used</u> <u>no</u>	<u>Cost</u>	
			<u>Suppl.</u> <u>1000 \$</u>	<u>Labour</u> <u>1000 \$</u>
125	226	1	37	138
200	362	1	59	220
400	711	1	117	429

Note: Pond remodeling every 10 years is not included in O&M

Table 10.5.4 PV/cap for AB system, US \$/cap

<u>Pop. density</u> <u>cap/ha</u>	<u>i=0%</u>		<u>i=5%</u>		<u>i=15%</u>	
	<u>Tot.</u>	<u>O&amp;M</u>	<u>Tot.</u>	<u>O&amp;M</u>	<u>Tot.</u>	<u>O&amp;M</u>
125	233	157	148	80	96	34
200	221	156	139	80	89	34
400	200	151	124	77	78	33

Table 10.5.5 User and plot charges for AB system,  
\$/cap,y or \$/plot,y

<u>Pop. density</u> <u>cap/ha</u>	<u>i=0%</u>		<u>i=5%</u>		<u>i=15%</u>	
	<u>plot</u>	<u>cap</u>	<u>plot</u>	<u>cap</u>	<u>plot</u>	<u>cap</u>
125	24	8	30	10	45	15
200	37	7	45	9	68	14
400	67	7	81	8	120	12

Note: Values from table 10.5.2 using criteria from chapter 6 regarding constant annual user expenses.






Figure 10.5.1

Differentiated total PV of AB system,  
30 y planning horizon, cf. table 10.5.2




Figure 10.5.2

AB system, accumulated total cash flow at  $i = 0\%$

## 11. MULTRUM

The Multrum was proposed in 1969 as an excreta disposal unit for low-cost high-density housing in developing urban areas, see SCANPLAN /27 & 28/.

### 11.1. Stage of development

Figure 11.1.1 shows the Multrum set-up and the construction of a composting compartment directly underneath the toilet slab in the privy. The scale is indicated and shows that the compartment volume is approximately  $.8 \text{ m}^3$ . The principles of the Multrum have been applied for many years in the Swedish "Clivus Multrum", but the Clivus system has a composting compartment volume of several cubicmeters. In Sweden the Clivus system is used primarily in remote dwellings or recreational housing areas, and often the use is intermittent. The Multrum with a small composting compartment and under tropical climatical conditions in high density housing areas is sofar unproven. The system is presently being investigated in field scale in Tanzania and Mali with international financial support, cf. IDRS /29/.

Comments as to feasibility of the Multrum concept can be only fragmentary and speculative at this stage of development and testing. Some questions and problems that are expected to be solved through the on-going African experiments are listed below:

1. Will the composting process work under the specified conditions?
2. Which dimensions and volumes should be applied for an optimal composting process to take place?
3. Will natural ventilation be adequate to supply oxygen for composting without drying out the excreta and thereby retard the microbial processes.

4. Will odour and fly nuisance be controllable?
5. Can organic kitchen waste be introduced into the Multrum system as proposed in the Swedish Clivus system?
6. What is an environmentally safe routine for emptying the compost compartment and spreading it on the ground?

In addition to these general problems are specific questions regarding modifications related to local circumstances such as:


- Temperatures
- Humidity
- Stagnant air
- Poor maintenance
- Surface-and ground water infiltration
- Survival of pathogens and larvae of worms

Considering all these yet unanswered questions it is noted that the authors have severe reservations regarding the feasibility of the Multrum in a high-density urban development. But the system is included in the study because it may economically represent a lowcost extreme, that is useful for the overall evaluation of alternative sanitary systems. Also, the public attention devoted to this system in recent years would justify the discussion.

#### 11.2. Plot development

The plot development is described without details because of the many unknowns mentioned above. Water supply is assumed to be through public stand pipes and there are no particular provisions included for waste water disposal on the plot.

Each plot must have been designated by one complete Multrum unit because proper use of the facility is critical to the success of the system.



scale 1:27




Figure 11.1.1

MR system concepts. Photocopy from  
WIINBLAD /27/

A rough estimate for the construction of the compost tank is developed. Based mainly on the indications of table 9.2.1 the following costs are assumed:

<u>Pop. density</u>	<u>Compost tank</u>
125 cap/ha	200 \$
200 cap/ha	250 \$
400 cap/ha	300 \$

Pre-manufactured modular units would be provided for each plot.

There are no accounted expenses for waste water removal and treatment due to the on-plot disposal of compost. With a good quality concrete construction a 30 years life time of the multrum can be anticipated. Maintenance is limited to annual or biannual compost removal and spreading on the plot.

### 11.3. Preliminary MR evaluation

Basic data for further evaluation, cf. chapter 12, are developed in the following tables 11.3.1-3. Graphical presentation of these data is found only in chapter 12.

Table 11.3.1 PV for MR system, 30 year lifetime

---

<u>Density</u> <u>cap/ha</u>	<u>i=0%</u> <u>\$ 1000</u>	<u>i=5%</u> <u>\$ 1000</u>	<u>i=15%</u> <u>\$ 1000</u>
125	2260	2260	2260
200	2846	2846	2846
400	3390	3390	3390

---

Table 11.3.2 PV/cap for MR system

---

<u>Density</u> <u>cap/ha</u>	<u>i=0%</u> <u>\$/cap</u>	<u>i=5%</u> <u>\$/cap</u>	<u>i=15%</u> <u>\$/cap</u>
125	65	65	65
200	51	51	51
400	30	30	30

---

Table 11.3.3 Annual user & plot charges for MR system.

---

<u>Density</u> <u>cap/ha</u>	<u>i=0%</u>		<u>i=5%</u>		<u>i=15%</u>	
	<u>\$/plot</u>	<u>\$/cap</u>	<u>\$/plot</u>	<u>\$/cap</u>	<u>\$/plot</u>	<u>\$/cap</u>
125	7	2.2	13	4.2	30	10
200	9	1.7	17	3.3	39	8
400	10	1.0	20	2.0	46	5

---





## 12. COMPARATIVE EVALUATION

Based on assumptions and calculatory results obtained for the five different sanitation systems, chapters 7 through 11, a comparative evaluation can be made.

It should be born in mind that the basic assumptions with respect to area, storm water, ground water level, slope of land, and population densities are identical for all five systems evaluated, cf. chapter 6. A few introductory remarks may be necessary:

1. For actual problems where the situation is similar to the one delineated through the above basic assumptions it may be relevant to use the results of this report for a relative consideration; e.g. compare economy and use terms like "% more expensive", etc.
2. For specific problems where the above basic assumptions do not apply properly the results should be used with extreme care. For example, if the ground water level is far below the surface the price of sewerage may be lower than indicated in this report.
3. Use of absolute values, e.g. \$/p,y for full sewerage per se should be avoided. Chapter 6 presents the data used for wages, trucks etc., but these data are typical only for an "average developing country" that may resemble those of an African state. Each country or region has its own characteristics that must be assessed properly before absolute numbers can be derived.

### 12.1 Service levels, WS & WWR

A summarized comparison of the different systems with respect to water supply (WS) and wastewater removal (WWR) is presented in table 12.1.1.

The FS requirement for a minimum water consumption (approximately 50 l/c,d) to secure proper function may severely limit the feasibility at an early stage of development. Only FS has such requirement for water consumption, because the settleables in this case are conveyed by the water to the treatment plant. On-plot water supply, preferably a multitap installation, is necessary.

None of the other WWR systems have this high water demand, which makes these very attractive where water is in short supply. Less water consumption may cause loss of convenience to the plot inhabitants depending on which sanitary system is chosen.

Assuming AP as a substitute for FS the loss of convenience to the plot family is fairly modest if recognizable at all. It should be added that the AP design has provision for increased future water consumption. The biannual removal of sludge deposits from the privy tank will hardly cause inconvenience to the plot inhabitants.

Table 12.1.1 WS & WWR service levels

System	WS		WWR	
	Type	Sanitary cons. l/p,d	Removal mode	waste type
FS	plot, multitap	50 (min.)	1)	2)
AP	plot	flex 4)	piped, grey & black	piped, grey & black
CM	plot or public	8	truck, only black	
JS	public stand	o 5)	truck, only black	
AB	public stand	flex	piped, grey & black	
MR	public stand	o	on site, black & org.3)	

- Notes: 1) grey means waste water from cooking and washing etc.  
 2) black means human excreta  
 3) org. means organic waste, e.g. from cooking.  
 4) flex means flexible water consumption e.g. anything from 10l/p,d and higher.  
 5) o means that no water is added to the excreta during the visit to the privy

JS does not require addition of water for handling of excreta. CM requires the addition of some 8 liters/p,d for flushing the siphon, but this modest amount does not require a plot tap, and the water needs not be high quality drinking water. A significant drop in service level should be acknowledged when proposing CM or JS systems in stead of FS or AP, because the former do not include provision for plot disposal of grey waste.

AB involves piped water supply via public standpipes and piped waste water removal, but in practice there will be no limits to the water consumption/capita. Grey waste will be generated and disposed of at the ablution block, which is a superior service compared to CM & JS. However, the overall service level of AB is inferior to that of FS or AP, because there is no provision for immediate plot disposal. It should emphasize that AB can be developed into a plot pipe connected system like FS or AP, if future development makes such change desirable.

The MR would require no water usage. Wet waste organics from food preparation may favourably be added to the composting tank, and among the six alternatives only MR will handle this particular waste flow. Similarly to JS & CM this system offers significantly less convenience to the plot inhabitants than the FS & AP alternatives. It is even debatable whether the service level is comparable to that of JS & CM, and only practical experience from actual use over a long period of time can clarify this question.

## 12.2 Health

The health evaluation criteria were introduced in chapter 6. Based on these concepts table 12.2.1 has been established. Some transmission routes are identified and examples of infectious diseases and their agents are listed.

Table 12.2.1 Health improvement following sanitary excreta removal at least public stand pipe water supply.

TRANSMISSION		EXAMPLES		IMPROVED HEALTH INDICATION					
Route	Contraction	Bio-agent	Disease	FS*	AP*	CM	JS	AB*	MR
	Ingestion	Salmonella	Typhoid	o	o	o	o	o	o
Water	Skinpenetration	Schistosomas	Schistosomiasis	+	+	+	(+)	(+)	(+)
		<u>mans., jap.,h</u>		+	+	+	(+)	(+)	(+)
<u>Anus-hand-hand-man</u>	Ingestion	Shigella	Dysentery	+	+	+	+	+	+
Insect-vectors	Breed in water	Anopheline	Malaria	+	+	+	+	+	+
		Culex p. fat.	Filariasis	+	+	+	+	+	+
		Aedes Aegypti	Yellow & Dengue fever	+	+	+	+	+	+
Food contamination	Ingestion	Salmonella	Salmonellosis	+	+	+	+	+	+
		Vibrio	Cholera	+	+	+	+	+	+
		Entamoebiasis	Amoebiasis	+	+	+	+	+	+
Man-soil-man	Dirt intake & food contamination	Ascaris	Round worm	+	+	+	+	+	?
		Trichuris	Whip worm	+	+	+	+	+	?
		Necator	Hook worm	+	+	+	+	+	?
Air	Eye & Nose	Aesthetical nuisance, e.g. odour and unsightly conditions		+	+	+	+	+	?

Notes: o = no improvement ) As compared to on the plot or  
 + = significant improvement ) other indiscriminate  
 - = impairment ) disposal of non treated excreta  
 \* = tap water available at sanitary site

The systems that are discussed herein would all significantly reduce the possibility of transmission of pathogens to man. Modification to this statement is necessary only for the Multrum, where evidence is still lacking with respect to technical feasibility and inactivation of pathogens.

Table 12.2.1 suggests that there is little if any difference between the systems in terms of improved health, compared to a situation with indiscriminate disposal. The indispensable prerequisite for this statement is that the systems are operated and maintained properly. Even though this requirement may be difficult to fulfil, it applies equally to all systems that an education programme is necessary, and that the task of education would tend to be similar for all systems.

Due to lack of data on operation the MR may turn out less satisfactory in terms of health protection compared to the other five systems.

Table 12.2.1 merely suggests qualitatively that health improvements are associated with the introduction of a sanitary waste disposal system. A more quantitative evaluation of the effect of introducing sanitary installations is found in a case study from the Philippines, WHO /30/. Four different communities all within larger urban settlements were studied. Cholera was known to be a problem through existing records, and it was used as the model disease for the comparative study which is outlined briefly in table 12.2.2

Table 12.2.3 shows a significant drop in occurrences of cholera as a result of improved sanitary conditions. There is no marked difference between effects of water supply or excreta removal or both.

Obviously there is a lower limit to the number of cholera cases even with improved sanitary installations. One possible explanation lies in the fact that the communities observed

Table 12.2.2 Background data for a Philippine study.  
Cholera reduction as related to sanitary improvements.

<u>Location name</u>	<u>Sanitary installations in test period</u>	<u>Families no</u>	<u>Persons no</u>
West Visayan	Non treated drinking water from a non controlled well with sucking pump. No latrines	134	743
Dawis	Municipally piped drinking water. No latrines but indiscriminate disposal of excreta; ocean beaches nearby with tidal action	135	803
Magsungay	Drinking water from public wells with hand pump. Excreta removal using CM squatting plate over a bottomless barrel placed in sandy soil. When the barrel is full it is moved. 4 families per privy	128	787
Sibucao	Piped drinking water. Excreta removal at public buildings with flush toilet and septic-tank. Ultimately the effluents go to a canal and into the sea. 30 persons/toilet.	135	756

Table 12.2.3 Results of a Philippine study on Cholera.

<u>Location</u>	<u>Sanitary Improvement</u>		<u>Population no</u>	<u>Cases of Cholera</u>	
	<u>DW</u>	<u>EXR</u>	<u>no</u>	<u>no</u>	<u>%</u>
West Visayan		Control	743	115	15
Dawis	+	-	803	33	4
Magsungay	-	+	787	35	4
Sibucao	+	+	756	33	4

Notes: DW - improved drinking water supply publicly piped and controlled  
EXR - improved excreta removal system

are in daily contact and interaction with neighbouring communities and persons, which means that pathogen transmission is not controlled only by local precautions.

Another observation in the Philippine study is that cholera propagation and persistence in the community is limited where sanitary improvements are made compared to the control community.

The conclusion to these statements and findings is that an excreta removal system may significantly reduce the occurrence of communicable diseases, and at least cholera seems an illustrative example in this respect. Introducing an excreta removal system will probably not eliminate communicable diseases, because societal interaction creates many transmission routes that are not controlled through proper excreta removal.

Referring to tables 12.2.1 - 3 it is assumed that any of the systems FS, AP, JS, CM, AB, and MR could significantly decrease incidents of disease outbreak and propagation if installed in a community. The basis for comparison is a similar community without a well planned excreta disposal system. There will always be a background disease rate depending on the general situation in the country or region, where the observed community is situated. Further, with the data available there is no firm ground for a ranking of the systems in terms of disease transmission risks. Only for the Multrum, MR, is it necessary to make the reservation that feasibility still remains to be proven through practical investigation.

### 12.3. Economy

The economical evaluation is based on data presented at the end of each of the separate chapters 7 - 11. It should be recalled that data for full sewerage, FS, have been established after careful examination of cost sensitivity to slope of pipes, water, consumption, etc in order to obtain a relevant basis for comparison with other alternatives.

12.3.1. Present value, PV, calculations

All calculations refer to a 30 year planning period over which all investments are depreciated (periods of 5, 10 and 30 years are used according to expected life time of equipment and civil works).




Figure 12.3.1.1

PV/cap, all systems compared, 125 cap/ha. 30 y planning horizon at different interest rates







Figure 12.3.1.2

PV/cap, all systems compared,  
 400 cap/ha. 30 y planning horizon  
 at different interest rates

PV calculations indicate the amount of money that would initially be required to cover all future expenses (investments and O&M) within the project period. For an interest

rate equal to zero,  $i = 0$ , PV is the total cash outflow over the project period. For  $i > 0$  PV is smaller than for  $i = 0$ , which reflects the fact that postponed payments require less present cash.

Figures 12.3.1.1 - 2 indicate the calculated PV's in \$/cap for 125 and 400 cap/ha and how PV is composed of investments and O&M expenses. MR requires the total investment right at the beginning of the project period, and consequently there is no effect of varying interest rate. FS and AP are similar with only insignificant O&M contributions to PV.

For AB, JS and CM the PV's are composed of initial investments, postponed investments, and regular O&M, where the latter contributes greatly to the total PV. Consequently PV becomes particularly sensitive to changes in interest rate.

Distinction between investment and O&M is very important since O&M is an on-going and often labour intensive activity. Investments may also be labour demanding, but the employment period will be of relatively short duration. O&M therefore tends to constitute a cash flow that is recycled locally, whereas investments demand a cash flow out of the community.

PV is often used by investors to evaluate "best choice" of investments. The calculation of PV involves all future revenues and expenses within the project period. In figures 12.3.1.1 - 2 only expenditures are considered, and consequently the best choice would be the one with the least PV indicated in the figures.

It should be stressed that PV is only an economical decision criterion. Many other aspects such as employment or scarcity of water may pose important criteria that need separate evaluation.

### 12.3.2 User charges

It is assumed that within the project period (30 years) an annual user charge must be paid. The charge should be constant (1975 \$), and payments are calculated respectively per plot and per capita. The charge is calculated so that present value of all future charge will equal that of all future expenditures with due regard to time of expenditure and interest rate, cf. chapter 6. Results of such calculations are presented in chapters 7 - 11, cf. tables 7.10.5, 8.5.5, 9.5.5, 10.5.5, and 11.3.3. Figures 12.3.2.1 - 2 give a graphical representation of these tables.

Obviously the user will face wide ranges of annual sanitation expenditures depending on the technical alternative. This is demonstrated in table 12.3.2.1

Table 12.3.2.1 User charge ranges for alternative sanitation systems.

Basis cap/ha	Interest rate %	Cheapest \$/y	1) Most expensive
			\$/y
125	0	AP 5	CM 11
	5	AP 7	FS 13
	15	JS 11	FS 30
200	0	AP 3	CM 8
	5	AP 5	CM 10
	15	JS 8	FS 19
400	0	AP 2	AB 7
	5	AP 3	AB 8
	15	AP & JS 6	AB 12

Notes: 1) MR would give the cheapest solution but is excluded from the comparison since the feasibility is yet un-proven.

The plot charges are derived easily when multiplying by 3, 5, and 10 for 125, 200 and 400 cap/ha respectively




Figure 12.3.2.1

User charges, \$/cap,y, all systems compared. 30 y planning horizon at different population densities and interest rates

Table 12.3.2.1 shows the cheapest and the most expensive alternatives, and it appears that expenditure per capita per year depends very much on population density as well as interest rate. A total range from 2 to 30 \$/cap,y is found.

Generally the most expensive alternative is 2 - 3 times as expensive as the cheapest, cf. 8/3, 10/5, and 19/8 for




Figure 12.3.2.2 User charges, \$/plot, y, all systems compared. 30 y planning horizon at different population densities and interest rates

200 cap/ha, table 12.3.2.1. This is valid for any interest rate and any population density. Similarly, for any chosen population density the expenditure may vary with a factor 2 - 3 depending on the applied interest rate.

For any population density and reasonably low interest rates the AP system is cheapest (next only to MR). For high pop-

ulation densities (400 cap/ha) the AP is cheapest even at high interest rates. Table 12.3.2.1 shows AP price levels of 2-3 \$/cap,y for 400 cap/ha, and 5-7 \$/y for 125 cap/ha for interest rates 0-5%. For densities of 400 cap/ha the price rises to 6 \$/cap,y for  $i = 15\%$ . At high interest rates the JS becomes competitive to AP for population densities 200 and 125 cap/ha. The reason is obviously that AP requires major investments at the beginning of the project period, which involves relatively high interest payment over the project period. JS has investments (trucks in particular) distributed regularly over the entire project period, which requires a relatively low total interest payment.

The most expensive alternative is either FS, CM, or AB. For small population densities and low interest rates CM becomes most expensive; cf. table 12.3.2.1 for 125 and 200 cap/ha. With increasing interest rate FS becomes most expensive, and again the reason is that essentially all capital must be invested at the beginning of the project period. At high population densities the AB becomes the most expensive alternative.

Between most expensive and cheapest alternative are systems that would need other than economical justification for possible selection, cf. below and the discussion above as to O&M and investment.

#### 12.3.4 Cost of water supply & waste water removal

The costs of water supply were indicated in chapter 6, table 6.2.1. Though data are scarce and relate mainly to East Africa it is deemed relevant to compare costs of water supply and waste water removal.

It should be kept in mind that the water supply prices are from existing distribution systems and a certain overhead for administration may be included, which is not the case for the waste water removal data.

Table 12.3.4.1 Relative WWR costs at different interest rates

Density <u>cap/ha</u>	i=5%		i=15%	
	AP + WS 1) \$/cap,y	WWR cost ratio %	JS + WS 2) \$/cap,y	WWR cost ratio %
125	7 + 13	35	11 + 2.5	81
200	5 + 8	38	8 + 1.8	82
400	3 + 7	30	6 + 1.6	79

Notes: 1) Cf. tables 12.3.2.1 & 6.2.1 from where it appears that AP is the most favourable WWR alternative at i=5%

2) Cf. tables 12.3.2.1 & 6.2.1 from where it appears that JS is the most favourable WWR alternative at i=15%

To indicate the magnitude of cost of WWR compared to WS + WWR table 12.3.4.1 lists the pertinent data for the economically most favourable WWR alternatives for two different interest rates.

Apparently the WWR cost ratio is influenced considerably by the interest rate. However, the reason is that the water supply is by plot tap in the case of AP, and by public stand pipe in the case of JS. Recalling the lack of accuracy of the water supply cost, cf. section 6.2, the above cost ratios are listed merely to inform about order of magnitude.

#### 12.4. Employment, supplies & education

##### 12.4.1. Employment

As mentioned already under economical considerations the same user expenditure may involve very different employment situations. Typically the FS & AP systems require limited O&M expenses and few labourers employed; whereas JS, CM & AB

would require a considerable number of employees to secure proper operation, cf. table 12.4.1. For example, the labour force is 10-30 times bigger for AB than for FS, and the ratio is very much dependant on population densities. The MR system is by nature the least labour demanding of all systems under evaluation.

Table 12.4.1 Annual O&M in terms of labour, trucks and supplies.

SYSTEM	I T E M	PERSONS PER HECTAR		
		125	200	400
Full Sewerage	Labour no <sup>1)</sup>	19	21	26
	Trucks no <sup>1)</sup>	1	1	1
	Labour 1000 \$	14	15	18
	Supplies 1000 \$	2	2	2
Aqua Privy	Labour no <sup>2)</sup>	16	18	23
	Trucks no <sup>2)</sup>	5	7	13
	Labour 1000 \$	22	27	44
	Supplies 1000 \$	6	9	16
JS & Vault & Truck	Labour no	84	97	117
	Trucks no	26	30	34
	Labour 1000 \$	68	76	90
	Supplies 1000 \$	39	46	54
CM & Vault & Truck	Labour no	124	151	221
	Trucks no	46	57	86
	Labour 1000 \$	100	119	174
	Supplies 1000 \$	68	85	129
Bucket & Ablution	Labour no	226	362	711
	Trucks no	1	1	1
	Labour 1000 \$	138	220	429
	Supplies 1000 \$	37	59	117
Multrum	Labour no			
	Trucks no			
	Labour 1000 \$		LOVE	
	Supplies 1000 \$			

Notes: 1) Jet cleaner  
2) Jet cleaner + vacuum trucks



A labour demanding WWR system may be attractive at an early stage of development where migration towards the cities typically is associated with an unemployment situation. But a general conclusion should be avoided and decisions made only after careful examination of problems pertinent to the region under investigation.

It should be kept in mind that table 12.4.1 applies to O&M costs, and these are only a fraction of total costs (and user expenditures). Information as to O&M versus total cost can be found e.g. in figures 12.3.1.1 -2.

#### 12.4.2 Supplies

The extremes of supply costs (fuel, electricity, tires, lubrication,...) are found in table 12.3.1 for FS (minimum  $\sim$  2000 \$/y). In any case the supply is merely a fraction of total O&M, and particularly so for piped WWR systems such as FS & AP.

#### 12.4.3. Education

One important component has been omitted from O&M, namely the cost of education of the users of new or remodeled sanitation facilities.

It must be emphasized that education, e.g. by sanitary inspectors, will be necessary over an extended period (years). Only through such education programmes will the health improvements become manifest after the installation of the system.

It is not justified to expect any significant difference in effects and costs between educational programmes pertinent to the different alternative sanitation schemes. Of course the elements of knowledge and practice will be different, but education will be necessary as to basic sanitary principles and disease control irrespective of which system may be introduced.

Therefore it is assumed that education and costs involved herein be included in any sanitation improvement programme. These costs have, however, been excluded in all calculations in the present report, because they would be essentially the same for all of the systems.

## 13. CONCLUSIONS

Waste water removal systems for urban housing in developing countries have been analyzed through a hypothetical case based on background data from Lagos, Nigeria. Some general and some specific conclusions can be drawn and these are presented below under individual headings. Six alternative systems have been considered:

- Full (conventional) sewerage (FS)
- Aqua privy with piped liquid disposal (AP)
- Japanese stool with vault, excluding sink waste (JS)
- Chiang Mai squatting plate, excluding sink waste (CM)
- House bucket and communal ablution blocks (AB)
- Multrum (MR)

### Best alternative

There is no universally best alternative, but the precedent analysis has demonstrated how several circumstances are important in the search of an optimal solution, e.g. density of population, slope of ground, water supply, interest rates, service level etc.

Population density is of particular importance. At high densities, e.g. above 400 cap/ha, the piped systems are more favourable from an economic point of view. At low densities, e.g. 125 cap/ha and less, the non-piped systems appear preferable - particularly when interest payment is taken into consideration.

The case study has been regarded a virgin land development, but the conclusion above holds true for remodelling of existing urban settlements

It should be noted that full sewerage (FS) and "piped system" are not synonymous; if only a low water consumption is available a piped system is still feasible (AP and AB), whereas FS is not.

### Health

For each of the systems FS, AP, JS, CM, and AB it may be concluded that they could significantly and equally well improve health relative to a situation without waste removal facilities. The prerequisite is good technical operation, which applies to all of the systems.

MR is not included in the statement because of lack of data.

### General service


Parameters have not been established to quantitatively indicate the level of user service generated by each of the systems under consideration. The difficulty may be demonstrated for example, by asking which is more convenient or satisfactory, 1) to use a waterless JS installation on ones own plot, or 2) to use a flush toilet and have a wash stand available in a communal ablution block 100 meter away?

A very rough categorization may be as follows, class I superior to II, etc:

Service class	I: FS, AP
Service class	II: JS, CM, AB
Service class	III: MR (?)

### User charges

In order to compare economically the different systems, the user charge is found to be an appropriate parameter, cf. section 12.3 above from which the subsequent figure is reproduced. The Multrum is merely of theoretical interest at the present, because the practical feasibility remains to be proven.



The user charges, as indicated in the figure, must be used with care because of the specific assumptions of this report, cf. chapter 6. A relative rather than an absolute evaluation is recommended. It is however interesting how the Aqua Privy appears favourable at low and medium interest rates, indicating that much attention should be paid to this system, particularly where little natural land slope and/or limited water supply discourage the use of other piped systems.

Full sewerage, FS

The FS system is evaluated in chapter 7. It should be re-emphasized that good technical performance of FS requires a minimum water consumption of app. 50 l/c,d.

The base design calculations led to the following conclusions regarding cost sensitivities to different FS designs:

- lowering the water consumption would not significantly reduce the project cost, regardless of population density, cf. figure 7.6.1.
- decreasing average slope of mains from 15 pm to 2 pm could decrease total cost of sewerage (PV = present value, 30 year project period) by as much as 35%; cf. figure 7.7.1.
- natural land slope exceeding 3 pm may significantly reduce the total cost of sewerage; the potential PV reductions are equivalent to savings on main sewers provided that gradients for these are acceptable.

Thus, FS cost is sensitive mainly to change of slope (ground, main sewer or both). The sensitivity of cost to the level of water consumption is insignificant.

In order to facilitate subsequent comparison the FS cost data were established as follows:

<u>Density</u> <u>cap/ha</u>	<u>FS cost in \$/capita, year</u>			
	<u>i = 0%</u>	<u>i = 5%</u>	<u>i = 15%</u>	
125	7 (.7)	13 (.5)	30 (.6)	Figures in paranthesis indicate O&M
200	5 (.6)	8 (.6)	19 (.5)	
400	3 (.5)	5 (.4)	10 (.3)	

The \$ values are transferred from table 7.10.5, and it is demonstrated that FS user charges are extremely sensitive to interest rates. The cost of O&M is negligible particularly at high interest rates, and the FS system tends to be capital intensive and labour extensive.

Aqua Privy, AP

The AP system is described and evaluated in chapter 8. The unique feature of AP is its flexibility to water consumption, e.g. a range from 20 - 400 l/p,d is acceptable without technical malfunction.

Cost data of the AP may be summarized as follows:

Density cap/ha	AP cost \$/capita, year			
	<u>i = 0%</u>	<u>i = 5%</u>	<u>i = 15%</u>	
125	5 (1.2)	7 (1.0)	16 (1.0)	Figures in paranthesis indicate O&M
200	3 (.8)	5 (.8)	10 (.7)	
400	2 (.7)	3 (.6)	6 (.6)	

The \$ values are transferred from table 8.5.5, and also in this case are the user charges highly influenced by interest rates. It appears that user charges will be used mainly to repay invested capital and interests, and only to a limited extent used for local employment, i.e. O&M.

House Vault, Japanese Stool, JS, and Chiang Mai, CM

There is virtually no minimum water consumption for these systems, but for CM a siphon flush requiring app. 0.8 l/visit must be encountered; cf. details in chapter 9.

Cost data for these two systems can be summarized as follows based on tables 9.5.5 and 9.5.4:

	Density cap/ha	JS & CM cost \$/capita, year			
		<u>i = 0%</u>	<u>i = 5%</u>	<u>i = 15%</u>	
<u>JS</u>	125	7 (3.6)	8 (3.5)	11 (3.5)	Figures in paranthesis indicate O&M
	200	5 (2.5)	6 (2.4)	8 (2.4)	
	400	3 (1.5)	4 (1.7)	6 (1.6)	
<u>CM</u>	125	11 (5.4)	12 (5.1)	17 (5.2)	Figures in paranthesis indicate O&M
	200	8 (3.9)	10 (4.0)	13 (3.8)	
	400	6 (2.9)	7 (2.9)	10 (2.9)	

With these two systems the user charge is less sensitive to interest rates, and a significant part, often 1/2, is kept in the society for O&M. It must be added though that the user charge as such tends to be higher than for AP, particularly at low interest rates. For high interest rates JS and CM require less user charge than FS.

Ablution Block, AB

This includes a piped sewer system, but there are no individual plot connections, neither for water supply nor for waste water removal. Details are given in chapter 10.

Cost data can be summarized as follows:

Density <u>cap/ha</u>	AB cost \$/capita, year			Figures in paranthesis indicate O&M
	<u>i = 0%</u>	<u>i = 5%</u>	<u>i = 15%</u>	
125	8 (5)	10 (5)	15 (5)	
200	7 (5)	9 (5)	14 (5)	
400	7 (5)	8 (5)	12 (5)	

For AB the user charge is less sensitive to interest rates than in the case of FS and AP. A significant proportion (30 - 70%) of the user charge is used for local employment. The user charges as such are generally comparable to those of JS and CM; they are comparable to those of AP at high interest rates and low population densities, but much higher at low interest rates and high population densities.

While CM and JS do not naturally develop into a piped system, the AB system could easily and logically be converted to a FS system.

Even though the initial AB capital investment is significant and comparable to that of FS for high population densities (cf. figures 12.3.1 1&2) it may be advantageous to use AB as a predecessor of FS at an early stage of development, particularly because water consumption may initially be too low for FS and because the AB system includes washing facilities (removal also of grey waste water).



New developments, new technology

Piped systems such as AP and AB offer promising alternatives for waste water removal from planned high-density low-income urban developments, mainly because these can be operated at low cost and at the low water consumption rates that may be typical at early stages of development. New technology is not needed to establish AP or AB systems in pilot or full scale, and therefore pilot or full scale experiments should be initiated as soon as possible, e.g. in some developing regions in African countries.

When planning for very low density urban settlements the non-piped WWR systems would seem attractive. The MR is an interesting proposal which is now being tested in small-scale in Tanzania. For the individual disposal type system there may be ample room for other developments and testing of new WWR technology, probably with emphasis on water saving systems.



## 14. REFERENCES

- /1/ GILBERT Associates, Inc.  
"Preliminary Economic Analysis and Master Plan for Sanitary and Industrial Sewerage, Storm Drainage and Refuse Disposal"  
Metropolitan of Lagos, 1966 Vol. I & II
- /2/ HILDEN, H.P.  
"Skrald, Storby og Miljø"  
København 1973, in Danish
- /3/ HEIDEN, E., MULLER, A.  
"Die Verwerthung der Städtischen Fäkalien"
- /4/ HYGIEJNISKE MEDDELELSER, 1858-59  
p. 237-46, in Danish
- /5/ ORTEGA, A., RYBCZYNSKI, W.,  
"Stop the 5 gallon flush". A survey of alternative Waste Disposal Systems  
Mc Gill University, P.O.Box 6070, Montreal 101, Quebec, Canada
- /6/ OLADAPO, O.O.  
"Advantages of sewerage systems over other methods for disposal of community wastes"  
WHO, Geneva, Sept. 25, 1973 (unpubl.)
- /7/ NEDECO, Project Senegal 22  
Plan Directeur, Tome I, Dwars, Heederik en Verkey, Amersfoort, Holland, 1972
- /8/ VINCENT, L.J., ALGIE, W.E. and MARAIS, van R.G.  
"A system of sanitation for low cost high density housing"  
C.C.T.A./WHO Symposium, Niamey, 1961
- /9/ IKEDA, I  
"Experimental Study on treatment of Night Soil by wet air oxidation process"  
Water Research 6 8(1972) 967
- /10/ ETHIOPIA  
Personal Communication, K.Tadesse
- /11/ Cf. /1/
- /12/ Cf. /10/

- /13/ WHITE, G.F., BRADLEY, D.J. and WHITE, A.V.  
"Drawers of water"  
University of Chicago Press, 1972
- /14/ ALUKO, T.M.  
Personal Communication for evaluation of urban  
waste disposal systems, 1974
- /15/ WHO course on coastal pollution control, private  
communications from participants 1970, 1971, 1972  
and 1973
- /16/ TOKYU  
"Technical data on vacuum trucks", Fall 1973  
Tokyu Car Manufacturing Co, Tokyo, Japan
- /17/ WILLIAMS, A.C., NASSAR, J.I.,  
"Financial Measurement of Capital Investments  
Management Science 12 11(1966) 851
- /18/ "NEW CIVIL ENGINEER"  
February 1976 U.K.
- /19/ GLOYNA, E.F.  
"Waste stabilization Ponds"  
WHO Monograph No. 60, 1971
- /20/ MARAIS, G. vR.  
"New factors in the design, operation and performance  
of waste stabilization ponds"  
Bull. WHO 1966, 34, 737-763
- /21/ MARA, D.D. Personal communication, 1972  
University of Kenya
- /22/ INSTITUTE OF WATER POLLUTION CONTROL,  
Technical Communication  
Domestic Sewage: Load per person per day  
Water Pollution Control, U.K. 1967, 193-196
- /23/ FROISE, S., BURGESS, S.J.  
"A dynamic programming approach to determine least  
cost strategies in urban drainage network design"  
FWPCF conference, Boulder, Col, 1975
- /24/ KAWASAKI  
"Our city"  
Private communication from Naoki Ohoi, Town Hall  
City of Kawasaki, Japan
- /25/ PRA information 2/75, Postbox 333  
Blindern, Oslo 3, 1975

- /26/ SHAW, V.A.  
"A system for the treatment of night soil and  
conserving tank effluent in stabilization ponds.  
Public Health Johannesburg (S.A.), 1963, 63, 17-26
- /27/ SCAN PLAN CONTACT  
"Housing in developing countries"  
Copenhagen, 1970
- /28/ SCAN PLAN CONTACT  
"Evaluation of waste disposal systems for urban low  
income communities in Africa"  
Copenhagen, 1970
- /29/ IDR news  
International Development Centre, 60 Queen Street,  
Box 8500, Ottawa, Canada K1G 3H9, May 22 1975
- /30/ WHO  
"Strategie de la lutte contre le cholera,  
Evaluation directe de l'assainissement en tant que  
moyen de lutte contre le cholera,  
Commission philippine du cholera, BD/CHOLERA/ 71.5
- /31/ Cf. /23/
- /32/ DANSK INGENIØRFORENINGS NORM for Afløbs installatio-  
ner (in Danish), 1 udgave august 1974, Copenhagen
- /33/ WPCF, Water Pollution Control Federation  
"Design and construction of sanitary and Stormsewers"  
WPCF Manual of Practice No 9, 1970  
Washington D.C. 20016 USA
- /34/ DANSK INGENIØRFORENING No. 10  
"Nye Dimensioneringsformler og diagrammer til  
beregning af kloakledningers vandføring"  
Copenhagen, Denmark 1974



## 15. ABBREVIATIONS

Generally applied abbreviations are the following:

AB	Ablution block, cf. chapter 10
AP	Aqua privy, cf. chapter 8
black waste	Human excreta
BOD	5-days biological oxygen demand
C	Collection of sewage
cap	capita, identical to p = person
CM	Chiang Mai house vault system, cf. chapter 9
d	day & night
DANIDA	Danish International Development Agency
DWF	Daily Water Flow , normally .85 x daily water consumption, e.g. 400+340 l/p,d
FS	Full sewerage, cf. chapter 7
grey waste	Waste water from washing and cooking
h	hour
i	interest rate (calculatory), year basis, cf. chapter 6
JS	Japanese Stool house vault system, cf. chapter 9
kWh	kilo watt hour - energy unit = $3.6 \times 10^6$ Joule
l	liter
mg	milligramme, $10^{-6}$ kilogramme
mo	month
MR	Multrum, cf. chapter 11
no	number
O&M	Operation & Maintenance
p	person, cf. cap
PI	Plot Installation
pm	per mille = per 1000 = o/oo
PV	Present Value of future expense or revenue, cf. chapter 6
T	Treatment of waste water
w	week

Cont.

WHO	World Health Organization
WS	Water Supply
WWR	Waste Water Removal
y	year = yr



## 16. APPENDICES

Two appendices, I & II, are presented below to further support the calculations on sewerage in chapter 7 and some of the generally applied unit costs.

### Appendix I

Sewer prices have been based on American practice, cf. American Society of Civil Engineers: "Design and Construction of Sanitary and Storm Sewers", ASCE Manual of Engineering Practice no 37. Prices have been updated and tables for direct cost estimates prepared by FROISE /31/ whose work was used to establish table A I.1

Table A I.1 Prices of Sewers, \$/m, US \$ 1975, after FROISE /31/

---

Pipe diameter mm	Depth of sewer (m)						
	1.1	1.3	1.5	2.0	2.5	3.0	5.0
100	8	9	12	19	22	29	71
150	11	13	15	22	27	34	77
200	13	14	17	24	30	43	77
250			20	26	30	45	79
300			20	26	30	45	81
350			22	29	32	48	81
400			24	31	34	51	87
450			28	34	37	54	90
500			33	40	43	59	99
600			40	50	53	69	109
700			55	62	68	85	131
800			70	81	85	104	147
900				90	97	113	166
1000				109	115	132	181
1100				125	133	152	205

---

Note: Prices include dewatering, but exclude removal and replacement of pavement.

---

Table A I.2 Prices of manholes, \$/unit, US \$ 1975, after FROISE /31/

Type	Use	Depth (m)			
		-1.0	1.0-1.8	2.0-4.0	4.0-
Type I	laterals only	100	-	-	-
Type II	∅ sewer 200-500 mm	-	300	550	1000
Type III	∅ sewer > 600 mm	-	-	1000	1250
Flushing shaft	middle of mains for cleansing	-	100	150	200

Prices for manholes have been estimated, FROISE/31/, according to the classification shown in table A I.2

Other unit costs have been estimated from own experiences in African countries or are obtained from persons or companies with experience in developing countries.

Table A I.3. Unit costs of miscellaneous civil works, US \$ 1975

Item	Cost, \$
Trenching (depth < 1.0 m)	1.2/m <sup>3</sup>
Excavation in bulk	1.5/m <sup>3</sup>
Excavation in bulk incl. backfill, grading & compacting	2.2/m <sup>3</sup>
Pond lining	0.5/m <sup>2</sup>
Concrete slabs (8 cm)	10/m <sup>2</sup>
Fencing	15/m
Concrete placed incl. form & reinforcement	100/m <sup>3</sup>
Concrete lining incl. mesh	75/m <sup>3</sup>

Appendix II

The trunk sewer design calculation has been summarized in the following table A II.1. Figure A II.1 explains the symbols used and shows the area and the trunk sewer layout. Results are utilized in chapter 7.




Figure A.II.1. Layout and Difications for sizing of trunk sewers.

1) ESTATE	Residential drainage area, ha	Lateral	Main	A		B		C	
				mm diam.	m trunk	mm diam.	m trunk	mm diam.	m trunk
OUTSIDE	286.4 272.8	o	o	700 700	400	800 800	400 170	1100 1100	400 170
A.		4655							2)
24.5 ha	272.8 218.2 189.4 13.6		4900	700 700 700 250	50 230 265 900	800 800 800 300 250	50 230 265 450 450	1100 1100 1000 400 350 300 250	50 230 265 320 140 150 290
B.		12010							
63.2 ha	100.6		12640	600 500 450 400	250 500 350 240	700 600 500 450	180 700 270 190	800 700 600	580 520 240
C.		7545							
39.7 ha	39.7		7940	400 350 300 250	90 240 200 300	450 400 350 300 250	140 200 160 120 210	600 500 450 400 300 250	180 180 120 120 130 100
E.		8540							
43.1 ha	66.2 38.6 15.5		8970	500 450 400 300 250	250 780 350 250 600	600 500 450 300 250	700 330 350 350 500	800 700 600 400 350	250 780 350 280 100

Table A II.1. Sizing of trunk sewers

							300	140	
							250	330	
	9.8		250	550	250	550	350	100	
							300	100	
							250	350	
	17.8		300	100	350	100	400	160	
			250	410	300	100	350	100	
					250	310	300	100	
							250	150	
<hr/>									
D.		7485							
			7870						
	38.6 ha	38.6		300	200	350	200	400	200
				250	990	300	320	350	320
						250	670	300	70
								250	620
				300	490	400	70	450	70
				250	370	350	390	400	350
						300	150	350	120
						250	250	300	100
								250	200
<hr/>									
G.		77.3							
			8835						
				9300					
	46.5 ha	54.6		450	460	500	650	700	450
				400	550	450	440	600	700
				350	320	400	240	500	170
				300	330	350	310	450	260
F.				250	1000	300	170	400	140
						250	850	350	120
	30.8 ha		5960					300	430
								250	390
				300	570	350	530	450	460
				250	590	300	230	400	200
						250	400	350	100
								300	120
								250	280
<hr/>									

Notes: 1) Letters refer to markings on figure A II.1.

2) Based on 2 x DWF + I